



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	C18E085	Project Name:	Allaso Olivine
NPDES Id. No.	NMR10059X & '5CC	Location:	6925 Alameda Blvd NE
3/6/2025	Owner	Contractor	
Operator	Titan Olivine, LLC	HB	
Contact name & title	Josh Rogers	Zach Gruen VP & Matthew Barnard SI	
e-mail	jrogers@titan-development.com	zachg@Hbconstruction.com & leer@	
Contact Phone #	505-998-0111	856-0404 & 250-2069	
COA Inspector	Chancellor English	Start/End Time:	2pm
Construction Phase:	interiors, landscaping		
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"
		311/Complaint	Follow Up
Weather at time of inspection?		cloudy	Temperature: ~ 60
Estimated date of last storm 0.25" or greater		11/7/2024	

Item Number	Deficiency/ Corrective Action		
1	The permit coverage was missing from the site perimeter in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5. The notice must be located so it is visible from the public road that is nearest to the active part of the construction site, and it must use a font large enough to be readily viewed from a public right-of-way.		
2			
3			
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	Yes	Latest report Date: 3/3/2025

Notes:	
The SWPPP is in Room 130	

City of Albuquerque Stormwater Inspector Signature and date: 3/7/2025
Contact information: Chancellor English 505-924-3325
cenglish@cabq.gov

Chancellor English