

Weather Event Inspection

Site Name:	<u>Mixed Use Alameda Development</u> <u>6110 Alameda Blvd NE, Albuquerque, NM 87113</u>	Inspector:	Kyle Grinold
Permit #:	C18E086 NMR1001TQ NMR1001U5	Inspection Frequency:	
Date of Visit:	Jul 7, 2021, 5:44:07 PM	Last Rain Event Wednesday, July 7, 2021, 0.49"	Last Precipitation Wednesday, July 7, 2021, 0.49" 48h Forecast --

Part 1: Walk through the facility and look for signs of erosion control measures that may have failed or been damaged from the recent rainfall event.

a. Site Inspection

1. Are there any erosion control structures damaged from the rain event?

☒ Yes

☐ No

Notes:

Repair silt fence at west pond, approx. 200' blown away from wood stakes. Repair silt fence at the east lot. Approx. 100'.

2. Are there signs of new ruts or gullies from the rain event?

☐ Yes

☒ No

Notes:

N/A

3. Are there signs of significant amounts of mud in the street or outfalls from the rainfall event?

☐ Yes

☒ No

Notes:

N/A

4. Are there any conditions that need immediate attention?

☒ Yes

☐ No

Notes:

Fabric fence repair at the west pond and east dirt lot.

Part 2: Inspection report summary.

b. Inspection Report Summary

1. Qualifications of Inspector:

Training and work experience – see inspector qualification page in the SWPPP.

2. Measures/Areas Inspected:

Site Perimeter, Paved access points, Surrounding inlets, Outfalls, Ponds.



INSPECTIONS PLUS

Weather Event Inspection

Site Name:	<u>Mixed Use Alameda Development</u> <u>6110 Alameda Blvd NE, Albuquerque, NM 87113</u>	Inspector:	Kyle Grinold
Permit #:	C18E086 NMR1001TQ NMR1001U5	Inspection Frequency:	
Date of Visit:	Jul 7, 2021, 5:44:07 PM	Last Rain Event Wednesday, July 7, 2021, 0.49"	Last Precipitation Wednesday, July 7, 2021, 0.49" 48h Forecast --

3. Observed Conditions:

Minor silt fence repairs required.
Sediment escaped from north lot to the
SW corner and sidewalk.

4. Changes Necessary to the SWPPP:

NO changes to the SWPPP.

5. Were there any discharges?

Yes

No

Notes:

Sediment escaped from north lot to the
SW corner and sidewalk. Designated
ponding.

6. What did the water look like at the time of the discharge?

☐

Clear

☐

Partly sandy

☒

Very sandy

Notes:

N/A

7. Was Inspection Conducted Within 24 Hours of Last Rainfall Over
1/4"?

Yes

No

Notes:

Weather Event 07/07/21= 0.490" per
NOAA weather mapping at the time of
inspection.

8. How much did it rain?

Reference precipitation values included with this form.

Notes:



INSPECTIONS PLUS

Weather Event Inspection

Site Name:	<u>Mixed Use Alameda Development</u> <u>6110 Alameda Blvd NE, Albuquerque, NM 87113</u>	Inspector:	Kyle Grinold
Permit #:	C18E086 NMR1001TQ NMR1001U5	Inspection Frequency:	
Date of Visit:	Jul 7, 2021, 5:44:07 PM	Last Rain Event Wednesday, July 7, 2021, 0.49"	Last Precipitation Wednesday, July 7, 2021, 0.49" 48h Forecast --

Certification & Signatures

Certification Statement:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Electronic Signature

X *Kyle Grinold*

Date
July 7, 2021 at 5:45:01 PM MDT

Title
Inspector



INSPECTIONS PLUS

Weather Event Inspection

Site Name:	<u>Mixed Use Alameda Development</u> <u>6110 Alameda Blvd NE, Albuquerque, NM 87113</u>	Inspector:	Kyle Grinold
Permit #:	C18E086 NMR1001TQ NMR1001U5	Inspection Frequency:	
Date of Visit:	Jul 7, 2021, 5:44:07 PM	Last Rain Event Wednesday, July 7, 2021, 0.49"	Last Precipitation Wednesday, July 7, 2021, 0.49" 48h Forecast --

There Are No Action Items