

July 31, 2020

**RE: STONE AGE CLIMING GYM PERMIT NUMBER BP-2019-33977
TRAFFIC CERTIFICATION FOR PERMANENT CERTIFICATE OF OCCUPANCY
RESPONSES TO COMMENTS:**

Planning Department
Building and Safety Division
Plaza Del Sol Building
600 2nd Street NW
Albuquerque, NM 87102

This letter is to acknowledge the comments given to us by Nilo Salgado, Ernie Gomez and Jeanne Wolfenbarger of the Transportation Department regarding the accessible path requirement between Stone Age Climbing Gym and Tin Can Alley. We are proposing a new ramp to be installed by means of two compliant handrails at a location adjacent to the Stone Age handicap parking stalls at a location which complies with slope requirement in all directions. Furthermore, we propose to provide a temporary barricade adjacent to the Stone Age handicap spaces that will direct disabled patrons to the Stone Age entrance only. This barricade would be removed once the permanent handrails are installed.

Please do not hesitate to contact me if you have any questions or concerns.

Respectfully,



Joe Slagle,
Slagle Architect Inc.



7-31-20