

CITY OF ALBUQUERQUE



September 6, 2018

Scott Steffen, P.E.
Bohannon Huston, Inc.
7500 Jefferson St NE Courtyard 1
Albuquerque, NM 87109

**Re: Campo Del Norte
Erosion and Sediment Control Plan
Engineer's Stamp Date 8-20-18 (C18E102)**

Dear Mr. Steffen,

Based upon the information provided in your submittal received 8-21-18, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and for Work Order approval with the following conditions:

1. A sediment BMP (filter sock or similar) should be placed at the downstream end of the street work in Alameda Blvd and Signal Ave.

2. The Cutback curb detail is not deep or wide enough. A detail showing approximate acceptable dimensions is included with this letter.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email