

CITY OF ALBUQUERQUE



Timothy M. Keller, Mayor

April 25, 2018

Scott Steffen, PE
Bohannon Huston, Inc.
7500 Jefferson St NE
Albuquerque, NM 87109

**RE: Campo del Norte
Revised Grading Plan
Engineer's Stamp Date: 04/24/18
Drainage Report
Engineer's Stamp Date: 03/22/18
Hydrology File: C18D102**

PO Box 1293

Dear Mr. Steffen:

Albuquerque

Based upon the information provided in your submittal received 04/25/2018, the Drainage Report and Revised Grading Plan is approved for action by the DRB for Preliminary Plat, Site Plan for Subdivision and Site Plan for Building Permit.

NM 87103

As a reminder, prior to obtaining Work Order approval, please pay the Payment in Lieu of \$25,324.54. (4,220.76 CF x \$6/CF) The first flush required is 4,220.76 cubic feet. The required first flush volume must be made using the attached City of Albuquerque Treasury Deposit form. The Owner needs to bring three copies to the Building Permits and pay the fee. Then provide Hydrology with one copy showing the receipt.

www.cabq.gov

If you have any questions, please contact me at 924-3995 or rbrissette@cabq.gov.

Sincerely,

Renée C. Brissette

Renée C. Brissette, P.E. CFM
Senior Engineer, Hydrology
Planning Department

