

CITY OF ALBUQUERQUE



April 9, 2019

Peter Larson, Members, LLC, aloharv@msn.com

Copy: Shawn Biazar, SBS Construction and Engineering, LLC, aecllc@aol.com

Site: Aloha RV Addition

Re: Drainage Ordinance (14-5-2-1) Violation for Erosion and Sediment Control

Dear Mr. Larson,

The following violation was observed at yesterday's inspection.

1. Earth disturbance has begun at the site and stormwater controls have not been implemented.

Photos are shown below:



Earth disturbed at site. No sediment BMPs.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

CITY OF ALBUQUERQUE



Earth disturbed at site. No sediment BMPs.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov



Earth disturbed at site. No sediment BMPs.

CITY OF ALBUQUERQUE

**Required Mitigation:**

1. Implement stormwater controls per approved Erosion and Sediment Control Plan.

If violations are not mitigated within 10 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you would like to schedule a follow-up inspection at a day and time of your convenience, prior to 10 days from the date of this letter please let me know.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov