

CITY OF ALBUQUERQUE



April 22, 2019

Peter Larson, Members, LLC, aloharv@msn.com

Copy: Shawn Biazar, SBS Construction and Engineering, LLC, aecllc@aol.com

Site: Aloha RV Addition

Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control and Construction Site Waste(s)

Dear Mr. Larson,

1. Self-inspection reports have not been submitted. Self-inspections and accompanying reports are required once every 14 days and within 24 hours after a precipitation event of 0.25 inch or greater.
2. The site is not posted.
3. The waste container was not covered/ no ability to cover.

Required mitigation:

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

1. Perform self-inspections and document conditions on an inspection report(s) and provide the report(s) to the City.

Self-inspection reports can be hand-delivered, e-mailed or kept on-site. If kept on-site, the location is to be communicated to the City and the location must be accessible to the City during regular work hours.

2. The site is to be posted per paragraph 1.5 of the NPDES CGP. The form to be completed as part of the posting requirement can be e-mailed to you if you like.
3. The waste container is to be covered when not in use and the means to cover (tarp or similar) is to be observed.

If the violations are not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you have any questions, you can contact me at 924-3420, ccherne@cabq.gov.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.