CITY OF ALBUQUERQUE

Planning Department Alan Varela, Director



Mayor Timothy M. Keller

April 11, 2024

Rick Bennett, RA RBA Architecture, PC 1104 Park Ave SW Albuquerque, NM

Re: Citizen Church North 7518 Oakland Ave NE Request for Certificate of Occupancy- 30 Day Temp Transportation Development Final Inspection Architects Stamp Date 10-24-22 (C19D005) Certification dated 2-27-24

Dear Mr. Bennett;

Based upon the information provided in your submittal received 4-8-24, Transportation<br/>Development has no objection to a <u>30-Day Temporary Certificate of Occupancy</u>. This letter<br/>serves as a "green tag" from Transportation Development for a <u>30-Day Temporary Certificate of<br/>Occupancy</u> to be issued by the Building and Safety Division.

Prior to issuance of a Permanent Certificate of Occupancy, the following items are to be addressed:

Albuquerque

- 1. The bike racks were not installed.
- 2. The pedestrian connection to the Oakland Ave ROW was not complete.

NM 87103

- The sidewalk culvert plate was not installed near the north side of the building.
  There was material stored in the parking lot.
- 5. The mailbox west of the Oakland Ave entrance was too close to the sidewalk.
- 6. The landscaping was not complete so the public sidewalk could not be inspected.

www.cabq.gov

If you have any questions, please contact me at <u>ccherne@cabq.gov</u> or (505) 924-3986.

Sincerely,

Curtis A Cherne

Curtis Cherne, P.E. Senior Engineer, Planning Dept. Development Review Services

C: Laurie Elliot, Yvette Lucero, Desiree Gonzales, Wendi Alcala, James Broomfield, cbaldwin@citizen.church