

CITY OF ALBUQUERQUE



April 7, 2017

Shakeel Rizvi, Nazish LLC: shaky1424@yahoo.com

Re: Drainage Control Ordinance (14-5-2-1) Violations for Erosion and Sediment Control

Dear Mr. Rizvi,

At today's inspection the following violations were observed:

1. The inlet protection in Signal Ave required maintenance
2. There was too much loose dirt on the south side of Signal without a sediment BMP. This much sediment would overwhelm the inlet protection.
3. Contractors were exiting the site onto Wilshire Ave. and there is no track-out pad.

Photos are shown below:



Inlet protection requires maintenance.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

CITY OF ALBUQUERQUE



Too much loose dirt on the south side of Signal without a sediment BMP.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov



Exiting onto Wilshire Ave. with no track-out pad.

CITY OF ALBUQUERQUE



Required mitigation:

1. Perform maintenance on inlet protection.
2. Provide sediment BMP for loose dirt in Signal ave. or remove loose dirt including the dirt pile.
3. Install track-out pad for exiting onto Wilshire Ave. or inform contractors not to exit onto Wilshire Ave.

If violations are not mitigated within 30 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you would like to schedule a follow-up inspection at a day and time of your convenience, prior to 30 days from the date of this letter please let me know.

If you have any questions, you can contact me at 924-3420.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.

Principal Engineer, Stormwater Quality
Planning Dept.