

CITY OF ALBUQUERQUE



November 17, 2017

Esmail Haidari, Senemar, LLC, esmailhaidari060@gmail.com
Copy: Shawn Biazar, aecllc@aol.com

Site: Rohan Subdivision

Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control

Dear Mr. Haidari,

The following violations were observed at today's inspection.

1. Earth disturbance has begun without installation of any sediment BMPS.

Photos are shown below:



No stabilized Construction Entrance to site and no silt fence along street.


PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

CITY OF ALBUQUERQUE



No silt fence along western edge.

PO Box 1293

Required Mitigation:

1. Install BMPS per the approved Erosion and Sediment Control Plan.

Albuquerque

If violations are not mitigated within 30 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

NM 87103

If you would like to schedule a follow-up inspection at a day and time of your convenience, prior to 30 days from the date of this letter please let me know.

www.cabq.gov

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.