

CITY OF ALBUQUERQUE



October 5, 2018

Esmail Haidari, Senemar, LLC, esmailhaidari060@gmail.com

Copy: Shawn Biazar, aecllc@aol.com

Site: Rohan Subdivision

Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control

Dear Mr. Haidari,

Self-inspection reports were not provided to the City per Violation Letter(s) dated 8-24-18 and 9-24-18.

Self-inspections and accompanying reports are required once every 14 days and within 24 hours after a precipitation event of 0.25 inch or greater.

Required mitigation:

1. Perform self-inspections and document conditions on an inspection report(s) and provide the report(s) to the City.

PO Box 1293

Self-inspection reports can be hand-delivered, e-mailed or kept on-site. If kept on-site, the location is to be communicated to the City and the location must be accessible to the City during regular work hours.

Albuquerque

Per the previous Violation letter, the City is assessing a fine of \$500. This fine is for one day.

NM 87103

Additional days may be added if the violation is not mitigated within ten days. In addition, your non-compliance is being reported to the New Mexico Environment Department, Surface Water Quality Bureau to aid in the determination if this issue is to be forwarded to the EPA.

www.cabq.gov

In addition, a hold has been placed on approving future submittals through Hydrology until mitigation is complete.

If you have any questions, you can contact me at 924-3420, ccherne@cabq.gov.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.