

CITY OF ALBUQUERQUE



October 16, 2018

Esmail Haidari, Senemar, LLC, esmailhaidari060@gmail.com

Site: Rohan Subdivision

Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control

Dear Mr. Haidari,

Self-inspection reports were not provided to the City per Violation Letter(s) dated 8-24-18, 9-24-18 and 10-5-18.

Self-inspections and accompanying reports are required once every 14 days and within 24 hours after a precipitation event of 0.25 inch or greater.

Per our phone conversation on 10-12-18, you are refusing to submit self-inspection reports or take responsibility for your site.

Required mitigation:

PO Box 1293

1. Perform self-inspections and document conditions on an inspection report(s) and provide the report(s) to the City.

Albuquerque

Self-inspection reports can be hand-delivered, e-mailed or kept on-site. If kept on-site, the location is to be communicated to the City and the location must be accessible to the City during regular work hours.

NM 87103

Per the previous Violation letter, the City is assessing a fine of \$5000. This fine is for ten days. It is to be paid within 30 days and/or prior to close-out of the Work Order, whichever comes first.

www.cabq.gov

Additional days may be added if the violation is not mitigated within ten days. In addition, your non-compliance is being reported to the New Mexico Environment Department, Surface Water Quality Bureau to aid in the determination if this issue is to be forwarded to the EPA.

In addition, a hold has been placed on approving future submittals through Hydrology and holds have been placed on permitting and inspections until mitigation is complete.

If you have any questions, you can contact me at 924-3420, ccherne@cabq.gov.

Sincerely,

Curtis Cherne, P.E.

Principal Engineer, Stormwater Quality
Planning Dept.