

CITY OF ALBUQUERQUE



January 29, 2013

Jarrood Likar, P.E.
Huitt-Zollars
6501 Americas Parkway NE
Albuquerque, NM 87110

**Re: Guardian Storage-Holly
Grading and Drainage Plan
Engineer's Stamp Date 1-24-2013 (C19/D056)**

Dear Mr. Likar,

Based upon the information provided in your submittal received 1-24-13, the above referenced plan can not be approved for Grading Permit or Building Permit until the following comments are addressed

- How are the roof flows entering the landscape areas? How and where are the curb cuts being placed, what are the sizes? A build note should be provided.

PO Box 1293

This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge. Prior to Certificate of Occupancy release, Engineer Certification per the DPM checklist will be required.

Albuquerque

If you have any questions, you may contact me at 924-3986 or Rudy Rael at 924-3977.

NM 87103

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Planning Dept.
Development and Building Services

www.cabq.gov

C: RR/CC
e-mail