

CITY OF ALBUQUERQUE



September 10, 2012

Jarrod Likar, P.E.
Huitt-Zollars
6501 Americas Parkway NE
Albuquerque, NM 87110

**Re: Guardian Storage-Holly Conceptual Grading and Drainage Plan,
Engineer's Stamp Date-no stamp- (C19/D056)**

Dear Mr. Likar,

Based upon the information provided in your submittal received 9-6-12, the above referenced plan is approved for Site Plan for Building Permit action by the DRB.

Please address the following comments when submitting for Building Permit:

- Show existing contours on the lot to the west.
- Provide flow line elevations on Holly Avenue.
- Additional elevations should be given on sidewalks.
- Standard flow and volume calculations per the DPM will be required.
- Provide a vicinity map.
- This review was performed for conceptual purposes only. Additional comments may be provided when submitting for Building Permit approval.

If you have any questions, you may contact me at 924-3986.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Planning Dept.
Development and Building Services

C: e-mail