

CITY OF ALBUQUERQUE



May 8, 2013

Mike Walla, PE
Walla Engineering
6100 Indian School Rd NE
Albuquerque, NM 87110

Re: Peak Motion, 7424 Holly Ave NE,
Request for Permanent C.O. –Not Accepted
Engineer's Stamp dated: 12-12-12, (C19/D057)
Certification dated: 5-6-13

Dear Mr. Walla,

Based upon the information provided in the Certification received 05-06-13, the above referenced Certification is not acceptable for a release of a Permanent Certificate of Occupancy by Hydrology. The following comments need to be addressed before a CO can be accepted.

PO Box 1293

- Under the Engineer Certification the width of the sidewalk culvert must be included in the exceptions section along with the length of the plate passed the property line toward the building. Also, verify the capacity of the sidewalk culvert.

Albuquerque

NM 87103

If you have any questions, you can contact me at 924-3986 or Rudy Rael at 924-3977.

www.cabq.gov

Sincerely,

Curtis A. Cherne, P.E.
Principal Engineer—Hydrology Section
Development and Building Services

RR/CC
C: e-mail