



DRAINAGE INFORMATION

LOCATION & DESCRIPTION

THE PROPOSED SITE IS 0.72 ACRES LOCATED ON THE SOUTH SIDE OF OAKLAND AVENUE WEST OF WYOMING BLVD. AS SEEN ON THE VICINITY MAP. THE SITE IS CURRENTLY DEVELOPED AS A BASEBALL FIELD WITH ASSOCIATED STRUCTURES. THE ADJACENT PROPERTY TO THE WEST IS UNDEVELOPED. THE PROPERTIES TO THE SOUTH AND EAST ARE DEVELOPED AS A CHURCH. THE PROPOSED DEVELOPMENT WILL BE AN ASSISTED CARE FACILITY.

FLOODPLAIN STATUS

THIS PROJECT, AS SHOWN ON FEMA'S FLOOD INSURANCE RATE MAP 35001C0141 G, DATED APRIL 2, 2002 IS NOT WITHIN A DESIGNATED 100-YEAR FLOODPLAIN. AN EXHIBIT WITH THE SITE SHOWN ON THE FIRM PANEL IS INCLUDED ON THIS SHEET.

METHODOLOGY

THE HYDROLOGY FOR THIS PROJECT WAS ANALYZED USING AHYMO SOFTWARE

THE 100-YR 6-HR DURATION STORM WAS USED AS THE DESIGN STORM FOR THIS ANALYSIS. THIS SITE IS WITHIN ZONE 3 AS IDENTIFIED IN THE CITY OF ALBUQUERQUE DEVELOPMENT PROCESS MANUAL, SECTION 22.2.

EXISTING DRAINAGE & REPORTS

THE SITE IS WITHIN THE NORTH ALBUQUERQUE ACRES DRAINAGE MANAGEMENT PLAN. THERE ARE TWO PREVIOUSLY APPROVED DRAINAGE PLANS ADJACENT TO THE SITE. THE SITE TO THE EAST, DRG.#C19D005 DATED 4/12/1985, WAS APPROVED FOR ALL DISCHARGE TO BE DIRECTED TO OAKLAND AVENUE VIA POND DISCHARGE PIPE. THE SITE TO THE SOUTH, DRG.#C19D0051, WAS APPROVED FOR ALL DISCHARGE TO BE DIRECTED TO ALAMEDA BLVD. THEREFORE, THERE ARE NO OFFSITE FLOWS THAT WERE TO HAVE IMPACTED SITE. THIS SITE DRAINS TO THE EXISTING CURB AND GUTTER IN OAKLAND AVENUE VIA SURFACE FLOW AND A SIDEWALK CULVERT.

DEVELOPED CONDITION

THE DETENTION POND AND DISCHARGE WAS NOT CONSTRUCTED AS REQUIRED ON LOT 14. THEREFORE, AN ADDITIONAL SIDEWALK CULVERT WILL BE INSTALLED ADJACENT TO THE PROPERTY LINE TO ACCOMMODATE THE 4.41 CFS AS QUANTIFIED IN PREVIOUS PLAN. THE SITE WILL BE DEVELOPED WITH A SINGLE STRUCTURE WITH ALL OF THE SITE RUNOFF ROUTED TO THE EXISTING CURB AND GUTTER. RUNOFF WILL BE ROUTED THROUGH THE TWO DETENTION PONDS THAT WILL DISCHARGE THROUGH INLET CONTROL PIPES. THE POND ROUTING DECREASES THE PEAK DISCHARGE TO BELOW THE RATE OF 3.47 CFS AS PRESCRIBED IN THE NAADMP. THE RUNOFF FROM SITE WILL BE ROUTED THROUGH THE PONDS ALONG EAST AND WEST PROPERTY LINES THEN DISCHARGED INTO OAKLAND AVENUE. OAKLAND AVENUE WILL CONVEY FLOW ALONG THE CURB TO INLETS LOCATED WEST OF THE SITE IN OAKLAND AVENUE. THE LACK OF INCREASE TO THE 100-YEAR PEAK RUNOFF, UTILITIES. DUE TO THIS DEVELOPMENT IS INSIGNIFICANT AND WILL HAVE NO ADDITIONAL IMPACT ON DOWNSTREAM FACILITIES.

<u>FIRST FLUSH</u>

THE DETENTION PONDS WILL HAVE ADDITIONAL DEPTH BELOW OUTFALL TO ACCOMMODATE THE FOLLOWING FIRST BE RESOLVED WITH A MINIMUM OF DELAY. FLUSH REQUIREMENTS:

ELENA GALLEGOS LAND GRANT NEW MEXICO PRINCIPAL MERIDIAN CITY OF ALBUQUERQUE BERNALILLO COUNTY, NEW MEXICO

LEGEND

FLOW ARROW

EL=11.28 PROPOSED ELEVATION

66.33 EXISTING ELEVATION

PROPOSED EASEMENT

PROPOSED GRADE

SLOPE ARROW

GRADE BREAK

4966—EXISTING CONTOUR

ROOF AREA = $14,450 \text{ FT}^2$

REQUIRED FLUSH VOLUME = $14,450 \text{ FT}^2 * 0.44/12 \text{ FT.} = 530 \text{ CU.FT.}$ PROVIDED FLUSH VOLUME = 310 CU.FT. + 130 CU.FT. + 90 CU.FT. = 530 CU.FT.

<u> </u>	ROLOGIC DATA - EXISTING									Z. CONTRACTO
BASINS	AREA (acres)	LAND TREATMENT PERCENTAGES BY TYPE				YIELD (cfs/ac)	Q100 (cfs)	V100-24 (acft)		DURING CO
		Α	В	С	D	 	(5.5)	(33.3)		3. CONTRACTO
Α	0.89	0	34	16	50	3.91	3.47	0.125		INTO EXISTI
HYDRO	DLOGIC DATA — PROPOSED								4. REPAIR OF	
BASINS	AREA (acres)	LAND TREATMENT PERCENTAGES BY TYPE				YIELD (cfs/ac)	Q100 (cfs)	V 100-24 (acft)		ACCUMULAT THE RESPO
		Α	В	С	D					5. ALL EXPOS
A-1	0.63	0	0	5	95	4.89	3.04	0.120	LEGAL DESCRIPTION	WATER ERC
A-2	0.26	0	0	36	64	4.46	1.18	0.044	LOT 13, BLOCK 3 UNIT 3, TRACT 2	
A*	0.89	0	0	14	86	3.45	3.06	0.163	WITHIN NORTH ALBUQUERQUE ACRES	
* INDI	CATES DIS	SCHARGE	AFTER PO	OND ROUT	INGS		IN	PROJEC	CTED SECTION 17, TOWNSHIP 11 NORTH, RANG	GE 4 EAST

INDICATES DISCHARGE AFTER POND ROUTINGS

WHICH RESULTS.

1. ALL WORK DETAILED ON THESE PLANS TO BE PERFORMED UNDER THIS CONTRACT SHALL, EXCEPT AS OTHERWISE STATED OR PROVIDED HEREIN, BI CONSTRUCTED IN ACCORDANCE WITH THE CITY OF ALBUQUERQUE STANDARD SPECIFICATIONS FOR PUBLIC WORKS CONSTRUCTION, 1986 EDITION, UPDATE

NOTES
THE ENGINEER HAS UNDERTAKEN LIMITED FIELD VERIFICATION OF THE

LOCATION, DEPTH, SIZE, OR TYPE OF EXISTING UNDERGROUND UTILITY LINES, MAKES NO REPRESENTATION PERTAINING THERETO AND ASSUMES NO

THE WORK IN ADVANCE OF AND DURING EXCAVATION WORK. THE

EXISTING UTILITIES. THE CONTRACTOR SHALL COMPLY WITH STATE

PERTAINING TO THE LOCATION OF THESE LINES AND FACILITIES IN

PLANNING AND CONDUCTING EXCAVATION, WHETHER BY CALLING OR NOTIFYING THE UTILITIES, COMPLYING WITH "BLUE STAKES" PROCEDURES,

THESE DRAWINGS DO NOT INCLUDE NECESSARY COMPONENTS FOR

RESPONSIBILITY OR LIABILITY THEREFORE. THE CONTRACTOR SHALL INFORM ITSELF OF THE LOCATION OF ANY UTILITY LINE IN OR NEAR THE AREA OF

CONTRACTOR IS FULLY RESPONSIBLE FOR ANY AND ALL DAMAGE CAUSED

STATUTES, MUNICIPAL AND LOCAL ORDINANCES, RULES AND REGULATIONS

CONSTRUCTION SAFETY WHICH SHALL REMAIN THE RESPONSIBILITY OF THE

THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, ARE INTENDED FOR USE ON THIS PROJECT AND IS NOT TO BE USED, IN

UNAUTHORIZED USE, THE USER ASSUMES ALL RESPONSIBILITY AND LIABILITY

WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN

AUTHORIZATION OF GND ENGINEERING, LLC IN THE EVENT OF

BY ITS FAILURE TO LOCATE, IDENTIFY, AND PRESERVE ANY AND ALL

THE EROSION PROTECTION SPECIFIED ON THIS PLAN IS THE MINIMUM RECOMMENDED. THE OWNER IS ENCOURAGED TO INCORPORATE EROSION RESISTANT LANDSCAPING ON AREAS WHERE EROSION MAY OCCUR SUCH AS SLOPES AND SWALES. THE OWNER IS RESPONSIBLE FOR THE INSTALLATION AND MAINTENANCE OF ALL EROSION CONTROL FEATURES NECESSARY TO PRESERVE THE DESIGN INTENT OF THE GRADING PLAN.

3. THE DRAINAGE INFRASTRUCTURE SHOWN ON THIS PLAN IS THE RESPONSIBLITY OF THE PROPERTY OWNER.

4. ALL DISTURBED AREAS OUTSIDE THE BUILDING PAD MUST BE RESEEDED

5. TWO (2) WORKING DAYS PRIOR TO ANY EXCAVATION, CONTRACTOR MUST CONTACT LINE LOCATING SERVICE, (260-1990) FOR LOCATION OF EXISTING

6. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL EXCAVATE AND VERIFY THE HORIZONTAL AND VERTICAL LOCATIONS OF ALL OBSTRUCTIONS AND EXISTING PAVEMENT. SHOULD A CONFLICT EXIST, THE CONTRACTOR SHALL NOTIFY THE ENGINEER OR SURVEYOR SO THAT THE CONFLICT CAN

EROSION CONTROL NOTES

INTO EXISTING RIGHT-OF-WAY.

THE RESPONSIBILITY OF THE CONTRACTOR.

1. CONTRACTOR IS RESPONSIBLE FOR OBTAINING A TOPSOIL DISTURBANCE PERMIT PRIOR TO BEGINNING WORK.

- 2. CONTRACTOR IS RESPONSIBLE FOR MAINTAINING RUN-OFF ON SITE DURING CONSTRUCTION.
- 3. CONTRACTOR IS RESPONSIBLE FOR CLEANING ALL SEDIMENT THAT GETS
- 4. REPAIR OF DAMAGED FACILITIES AND CLEANUP OF SEDIMENT ACCUMULATIONS ON ADJACENT PROPERTIES AND IN PUBLIC FACILITES IS
- 5. ALL EXPOSED EARTH SURFACES MUST BE PROTECTED FROM WIND AND

WATER EROSION PRIOR TO FINAL (CITY) ACCEPTANCE OF ANY PROJECT.

THE Group 300 Branding Iron Rd. SE Rio Rancho, New Mexico 87124

CITY OF ALBUQUERQUE PUBLIC WORKS DEPARTMENT ENGINEERING DEVELOPMENT GROUP ASSISTED LIVING HOME LOT 13, BLOCK 3, UNIT 2, TRACT 2, NAA

Mo./DAY/YR. Mo./DAY/YR. DESIGN REVIEW COMMITTEE | CITY ENGINEER APPROVAL

EXISTING WALL PROPOSED WALL CITY PROJECT No.

Phone:(505)514-0995

GRADING & DRAINAGE PLAN

 $\begin{array}{c|c} z_{\text{ONE MAP NO.}} & z_{\text{ONE MAP NO.}} & z_{\text{ONE MAP NO.}} \end{array}$ DRB NO. 1010273