



Luna Vita
Stillbrook Homes
General Permit SWPPP Inspection



7011 WILSHIRE AVE NE
ALBUQUERQUE, NM
87113



Last Rain Event
Saturday, August 1, 2020,
0.67"

Last Precipitation
Tuesday, August 25, 2020,
0.01"

48h Forecast
23% Chance of
Rain

Inspection Date and Time	Completed by	Frequency	Permit #
Aug 24, 2020, 2:00: 43 PM	Jeff Hart	Weekly on specific day -	C19E066 NMR10028V NMR10028U NMR10028V NMR10028U C19E066

Inspection Form Instructions - Review each question for this inspection carefully, then answer YES, NO, or N/A (not applicable). If any of the items below are out of compliance, press the "Add Action Item" button above to add a corrective action.

General Information

Inspector's Qualifications - Trained and work experience - see inspector qualification page in section 2 of the SWPPP.

Type of Inspection:

☒ Regular

☐ During storm event

☐ Post storm event

Weather Information

Last Storm Event Information - For information on the last storm event, see the weather event information at the end of this inspection.

Weather at time of this inspection?

☐ Clear

☐ Cloudy

☐ Rain

☐ Sleet

☐ Snowing

☐ High Winds

☒ Partly Cloudy

Have any discharges occurred since the last inspection?

☐ Yes

☐

☐ **No**

If yes, what did the water look like at the time of the discharge?

Are there any discharges at the time of this inspection?

~~Yes~~

☐ **No**

If yes, what did the water look like at the time of the discharge?

Is a rain gauge installed on site?

~~Yes~~

☐ **No**

If yes, where is it located?

Nearby gauge, NOAA, COCORHAS and Weather Underground monitored as secondary resources.

Has the Rain Event Page been filled out?

☐ **Yes**

~~No~~

Are there SDS sheets on site?

☐ **Yes**

~~No~~

If yes, where are they located?

Inspectors log updated. SDS sheets on site with Super.

If construction ceases on the site for more than 14 days, the site must be stabilized until construction resumes.

Date Construction Stopped

Date Construction Resumed

Measures Taken to Stabilize the Site:

Construction Phasing

Verify what stage of construction the project is in, and record dates when activities started and were completed.

Installed BMPs

~~Not Started~~

~~Started~~

☐ **Completed**

Started: 02/20

Completed: 02/20

Site Clearing and Grading

~~Not Started~~

~~Started~~

| **Completed**

Started: 02/20

Completed: 03/20

Installing Utilities

~~Not~~

~~Started~~

| **Started**

~~Completed~~

Started: 04/20

Completed:

Building Structure

~~Not~~

~~Started~~

| **Started**

~~Completed~~

Started: 03/20

Completed:

Paving and Walks

~~Not~~

~~Started~~

| **Started**

~~Completed~~

Started:

Completed: Street in place

Final Grading/Stabilize Site

Started: 07/20

Completed:

Other

Started:

Site-specific BMPs

The corrective actions initiated and date completed are in the Corrective Action Log

List of BMPs Installed:

Block Wall Portable Toilet Stabilized Construction Entrance Staging Area Swale Retaining wall Drop Inlet Protection.

Are all of the above controls installed?

☒ **Yes**
☐ ~~No~~

Do any of the above controls need maintenance?

☒ **Yes**
☐ ~~No~~

If any of the controls have not been installed or require maintenance, please list the control and explain.
Please see the "Action Item" log.

Are the BMPs shown on the map?

☒ **Yes**
☐ ~~No~~

Were there any changes to the SWPPP?

☐ ~~Yes~~
☒ **No**

Has the SWPPP been updated?

☐ ~~Yes~~
☒ **No**

Were the changes to the SWPPP implemented within 7 days?

☐ ~~Yes~~
☒ **No**

List any new BMPs needed:

Cut back behind the curb, street sweeping, debris collection.

Notes:

Oversight Issues

A list of corrective actions will be supplied with this inspection.

1. Are all slopes and disturbed areas not actively being worked properly stabilized?

Implemented?

☒ **Yes**
☐ ~~No~~
☐ ~~N/A~~

Maintenance Required?

☐ ~~Yes~~
☒ **No**
☐ ~~N/A~~

2. Are natural resources (e.g., streams, Arroyos, mature trees, etc.) protected with barriers or similar BMPs?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

3. Are perimeter controls and sediment barriers adequately installed (keyed into substrate) and maintained?

Implemented?

~~Yes~~

| **No**

~~N/A~~

Maintenance Required?

| **Yes**

~~No~~

~~N/A~~

4. Are discharge points and receiving waters free of any sediment deposits?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

5. Are storm drain inlets properly protected?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

| **Yes**

~~No~~

~~N/A~~

6. Is the construction exit preventing sediment from being tracked into the street?

Implemented?

☒ **Yes**
☐ ~~No~~
☐ ~~N/A~~

Maintenance Required?

☐ ~~Yes~~
☒ **No**
☐ ~~N/A~~

7. Is trash/litter from work areas collected and placed in dumpsters?

Implemented?

☒ **Yes**
☐ ~~No~~
☐ ~~N/A~~

Maintenance Required?

☒ **Yes**
☐ ~~No~~
☐ ~~N/A~~

8. Are washout facilities (e.g., paint, stucco, concrete) available, clearly marked, and maintained?

Implemented?

☒ **Yes**
☐ ~~No~~
☐ ~~N/A~~

Maintenance Required?

☐ ~~Yes~~
☒ **No**
☐ ~~N/A~~

9. Are vehicle and equipment fueling, cleaning, and maintenance areas free of spills, leaks, or any other deleterious material?

Implemented?

☒ **Yes**
☐ ~~No~~
☐ ~~N/A~~

Maintenance Required

☐ ~~Yes~~
☒ **No**

~~N/A~~

10. Are materials that are potential storm water contaminants stored inside or under cover?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

11. Are non-storm water discharges (e.g., wash water, dewatering) properly controlled?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

12. Has the Site map been updated to reflect current conditions?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

13. Is the NOI posted?

Implemented?

| **Yes**

~~No~~

~~N/A~~

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

14. Were previous corrections made within 7 days of last inspection or before the next storm event?

Implemented?

~~Yes~~

~~No~~

| **N/A**

Maintenance Required?

~~Yes~~

| **No**

~~N/A~~

Walk through facility and look for signs of pollution including paint, solvents, chemicals, solid waste, oil, and fuel.

Are there any signs of hazardous materials being exposed to storm water runoff?

~~Yes~~

| **No**

Have there been any reportable quantities releases of hazardous materials?

~~Yes~~

| **No**

Additional Notes

Certification

Certification Statement:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Electronic Signature

X *Jeff Hart*

Date

August 25, 2020 at 1:16:53 PM MDT

Title

Senior Inspector

Weather History

☒ Precipitation Recorded ☐ No Precipitation ☐ Missed or data unavailable

August

1 st	⊘	2 nd	⊘	3 rd	⊘	4 th	⊘	5 th	⊘	6 th	⊘	7 th	⊘
8 th	⊘	9 th	⊘	10 th	⊘	11 th	⊘	12 th	⊘	13 th	⊘	14 th	⊘
15 th	⊘	16 th	⊘	17 th	0	18 th	0	19 th	0	20 th	0	21 st	0
22 nd	0	23 rd	0	24 th	0.01"								

All precipitation totals are obtained from the National Oceanic and Atmospheric Administration (NOAA). Precipitation readings are based on the latitude and longitude for each site as entered into complianceGO. Occasionally NOAA fails to return/record data. Days where this occurs are so indicated.

Action Items									
Title	Inspector	Date	Priority	Location	Description	Status	Closer	Notes	Imgs
Sediment and Erosion Control Management	Jeff Hart	August 24, 2020	Immediate	8604, 8608, 8615, 8604, 8605- Luna Vita	Maintain the 4" cut back behind the curb. Curb sweep when complete.	Open			
Remove domestic and construction debris from the lots.	Jeff Hart	August 24, 2020	Immediate	8601, 8605, 8604, 8615 Luna Vita	Remove domestic and construction debris from the lots: 8601, 8605, 8604, 8615 Luna Vita	Open			
Sediment and Erosion Control Management	Jeff Hart	August 24, 2020	Immediate	Wilshire at Louisina.	Repair the Drop Inlet Protection on Wilshire at Louisina. Wattle removed from the throat of inlet.	Open			