

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

July 6, 1999

Bruce Stidworthy
Bohannan-Huston Inc.
7500 Jefferson NE
Albuquerque, NM 87109

RE: GRADING & DRAINAGE PLAN FOR VINEYARD PARK (C-20/D22)
RECEIVED JUN 16, 1999 FOR GRADING PERMIT & WORK ORDER ENGINEER'S STAMP DATED 6/16/99

Dear Mr. Stidworthy:

Based on the information included in the submittal referenced above, City Hydrology accepts the Grading Plan for Grading Permit. Prior to Work Order, the following comments must be addressed:

FIRM #35001C0141 D, effective date 9-20-96, indicates that there is a FHZ A0 depth 1" along the south edge of the Park. Note this in the DMP and show the FHZ boundary on Sheet 3. If the Park develops further before the North Domingo Baca Arroyo is improved, then an erosion set back will be required.

If I can be of further assistance, You may contact me at 768-2727.

Sincerely,

John P. Curtin, P.E.

Project Manager, PWD/Hyd

c: Inspector

PROJECT TITLE: VINE YARD PARK ZONE ATLAS/DRNG. FILE # CZO TOWN	
DRB #: EPC #:	work order #:
LEGAL DESCRIPTION:	
CITY ADDRESS:	
ENGINEERING FIRM: BOHANNAN-HUSTON INC. ADDRESS: 7500 JEFFERSON NE, ALB. NM 87109 OWNER:	PHONE:
TYPE OF SUBMITTAL: DRAINAGE REPORT DRAINAGE PLAN FINAL GRADING & DRAINAGE PLAN GRADING PLAN EROSION CONTROL PLAN ENGINEER'S CERTIFICATION OTHER PRE-DESIGN MEETING: YES NO COPY PROVIDED	CHECK TYPE OF APPROVAL SOUGHT: SKETCH PLAT APPROVAL PRELIMINARY PLAT APPROVAL S. DEV. PLAN FOR SUB&D. APPROVAL S. DEV. PLAN FOR BLDG. PERMIT APPROVAL SECTOR PLAN APPROVAL FINAL PLAT APPROVAL FOUNDATION PERMIT APPROVAL BUILDING PERMIT APPROVAL CERTIFICATE OF OCCUPANCY APPROVAL CERTIFICATE OF OCCUPANCY APPROVAL PAVING PERMIT APPROVAL S.A.D. DRAINAGE REPORT DRAINAGE REQUIREMENTS SUBDIVISION CERTIFICATION OTHER DEC (SPECIFY)
DATE SUBMITTED: 6/16/18 BY: BRUCE G., BHI	
Revised 02/98	

HYDROLOGY SECTION

F:\forms\DRAINAGE INFO SHT.doc - 09/30/98

1-1KM #3500120141