

# CITY OF ALBUQUERQUE



July 18, 2016

Philip W. Clark, PE  
Clark Consulting Engineers  
19 Ryan Rd  
Edgewood, NM 87015

**Re: Signal Pointe  
Request for Pad Certification - Not Accepted  
Engineer's Stamp Date 9-15-15 (C20D070)  
Certification date: 7-15-16**

Dear Mr. Clark,

Based upon the information provided in your submittal received July 15, 2016, the above referenced Certification is not approved for building permit by Hydrology. Please address the following:

PO Box 1293

Albuquerque

New Mexico 87103

1. Provide spot elevations around all pads.
2. Provide finish grade elevations on both sides of scour wall. There appears to be additional fill along the outer wall not accounted for.
3. Show permission to disturb the grades from property owners north and east of Signal Pointe subdivision limits.
4. Reseed disturbed areas outside of Signal Pointe subdivision as to restore to original condition.

If you have any questions, you can contact me at 924-3986 or Totten Elliott at 924-3982.

www.cabq.gov

Sincerely,

Abiel Carrillo, P.E.  
Principal Engineer, Planning Department  
Development and Review Services

TE/AC

C: email      File