

City of Albuquerque Stormwater Construction Site Inspection Report

General Information									
Project Name:		Amarand							
Location:		9100 Holly Ave NE		ESC File No.	C20E079		NMR10025V		
Site Contact Name &		Xenia - Paaru		Phone: (o)		505-307-1501			
Agency		si@paarugroup.com		Phone: (m)		-			
Owner		Hemal Patel - Paaru Builders hemal@paarugroup.com			505-271-128	8			
Owner's e-mail Inspection Date:				Phone: (m)					
	water Inspecto	09/09/20 Start/End Time: 1030/1100hrs r: Timothy E. Sims							
	ction Phase:	vertical							
Type of Inspection: x		Regular	Storm Event	Post Storm Event >0.25" 311/Complaint Follow Up					
.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		negulai				original for the second s	l ollow op		
Weath	er at time of i	nspection?	Cloud	dy	Tempe	erature: ~	47*		
Estimated	l date of last s	storm 0.25" or	greater			7/25/2020			
Item									
Number			Deficienc	y/ Correctiv	e Action				
1	Rain guage not witnessed on site. Please clarify most recent rain fall on SWPPP reports and								
	provide rain guage for the project site.								
2	Trackout on Holly requires mirigation prior to end of day today. A follow up occurs tomorrow.								
3	Track out pad to site from Holly requires mitigation.								
4	Sediment in street requires mitigation. A follow up will occur tomorrow.								
5	Inlet BMP's require mitigation. Please provide inlet protection								
6	Sediment BMP's around the perimeter requires maintenance								
7	Washout on the NE corner of building (appears to have generated from 2nd floor window)								
	requires mitigation.								
8	Construction and domestic waste not in acceptable refuse location.								
9	Material storage of sheetrock and portland not protected from weather. Store in acceptable								
	location.								
10	Mitigate all concrete washouts on site.								
2.1	Discharge off site?	(Y/N)	No						
4	-	tion Reports		Latest roy	oort Date:	9/8/20	20		
4	Jen inspec	tion reports		Latest le	port Date:	5/0/20	20		

Notes:	inspection conducted practicing safe social distancing				
All issues are noted on Contractor's provided SWPPP self-inspection report from "814"					

City of Albuquerque Stormwater Inspector Signature and date:Contact information:Timothy E. Sims - (505) 803-6155tsims@cabq.gov09/09/20