

## City of Albuquerque Stormwater Construction Site Inspection Report

General Information							
ESC File No.			Project Name:	Holl	Holly Senior Living / Amaran Senior Living		
NPDES Id. No. NIVIR10					9100 Holly		
	1/2020	Property Ow			Contractor		
Operator		Mark11s, LLC			Paaru Group		
Contact name & title					Mike Hart, SI		
Contact Phone #		<b> </b>			si@paarugroup.com m 410-6578 o 271-1288		
COA Inspector		Doug Hughes			Start/End Time: 2:30-3:30PM		
Construction Phase:					rtical		
Type of Inspection:		Regular	Storm Event	Post Storm	Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection? Clear Temperature: ~							76
Estimated date of last storm 0.25" or greater							
Item							
	Deficiency/ Corrective Action						
Number							
1	BMPs (silt fence) maintenance needed. Construction entrance missing.						
2	Washout						
3	Construction and domestic waste						
	Construction and domestic waste						
4							
2.1	Discharge off site?	(Y/N)	No				
4	Self Inspect	tion Reports		Latest re	port Date:	9/21/20	720
	Jen mapee	tion reports		Latestie	port Bate.	3/21/20	<i>3</i> 20
Notes:							

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Doug Hughes (505) 924-3420

jhughes@cabq.gov

9/23/20

James D. Hughes