

INSPECTION REPORT**GENERAL INFORMATION**

DATE OF INSPECTION: 8/24/2020

COMPANY NAME: Paaru

PROJECT NAME: Holly Ave Construction

LOCATION: 9100 Holly Ave NE ,Albuquerque,New Mexico,87122

TRACKING NO: NMR100000

COMPLIANCE EVALUATION: **Unsatisfactory**

TYPE OF INSPECTION: 14Day

START TIME: 8:15 AM

END TIME: 8:45 AM

INSPECTOR'S NAME: Kasey Anderson

INSPECTOR'S TITLE: Environmental Inspector

INSPECTOR'S QUALIFICATIONS: Storm Water Qualified Person

INSPECTOR'S CONTACT: 505-280-7766

PHASE OF CONSTRUCTION: ☒ Clear and Grub ☐ Excavation ☐ Building (vertical)
☐ Rough Grading ☐ Infrastructure ☐ Final Grading
☐ Final Stabilization

WEATHER INFORMATION

HAS A STORM EVENT OCCURRED SINCE THE LAST INSPECTION? ☐ Yes ☒ No

WEATHER AT TIME OF THIS INSPECTION: Clear

TEMPERATURE: 76

HAVE ANY DISCHARGES OCCURRED SINCE THE LAST INSPECTION? ☐ Yes ☒ No

ARE ANY DISCHARGES OCCURRING NOW? ☐ Yes ☒ No

ARE ANY PORTIONS OF YOUR SITE UNSAFE TO INSPECT? ☐ Yes ☒ No

POLLUTION PREVENTION, SEDIMENT AND EROSION CONTROL BMP'S

#	S&E/P2 CONTROLS	MAINTENANCE	CORRECTIVE ACTION	LOCATION	QUANTITY	UNIT	PHOTO
1	Construction Entrance	Remove	None	Remove and clean up broken lumber being used as a ramp for the NE construction entrance. This would be considered a road hazard.	1	EA	Yes
2	Construction Entrance	None	Upgrade	Not much rock left in the NW construction entrance to prevent track-out; recommend adding more or replacing. Clean up sediment on Holly Ave.	1	EA	Yes
3	Silt Fence	None	Replace	Reset or replace silt fence and wattle gap along northern fence, near utility box.	20	LF	Yes
4	Wattles/Socks/Log Roll	None	Upgrade	Close or cover gap in wattles along northern fence, near the NW corner of the building.	5	LF	Yes
5	Wattles/Socks/Log Roll	None	Replace	Replace wattle around the drain eastern drain inlet in front of the site.	1	EA	
6	Debris or Waste	Clean	None	Clean up Amaraan sign and debris in SW corner of site.	2	EA	Yes
	Debris or Waste	Clean	None	Clean up Amaraan sign and debris in SW corner of site.	2	EA	Yes

GENERAL SITE INSPECTION ITEMS

#	INSPECTION ITEM	INSPECTOR'S OBSERVATION	ACTION REQUIRED?	NOTES
---	-----------------	-------------------------	------------------	-------

1	Is the SWPPP signage clearly posted with the correct information and properly displayed at an obvious perimeter location?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	Permit information has been replaced on the board.
2	Are steep slope areas not actively being worked properly stabilized?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
3	Are disturbed areas not actively being worked properly stabilized?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
4	Are natural resource areas (e.g. streams, wetlands, mature trees, etc.) protected with barriers or similar BMPs?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input checked="" type="radio"/> Yes <input type="radio"/> No	Reset or replace silt fence and wattle gap along northern fence, near utility box. Close or cover gap in wattles along northern fence, near the NW corner of the building. Replace wattle around the drain eastern drain inlet in front of the site.
5	Are discharge points and receiving waters free of any sediment deposits?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input checked="" type="radio"/> Yes <input type="radio"/> No	Remove and clean up broken lumber being used as a ramp for the NE construction entrance. This would be considered a road hazard. Not much rock left in the NW construction entrance to prevent track-out; recommend adding more or replacing. Clean up sediment on Holly Ave.
6	Is trash/litter from work areas collected and placed in covered dumpsters?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input checked="" type="radio"/> Yes <input type="radio"/> No	Clean up Amaraan sign and debris in SW corner of site.
7	Are washout facilities (e.g. paint, stucco, concrete) available, clearly marked and maintained?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
8	Are vehicle and equipment fueling, cleaning, and maintenance areas free of spills, leaks or any other deleterious material?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
9	Are materials that are potential stormwater contaminants stored inside or in containers?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
10	Are offsite flows entering the construction site?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
11	Is there any evidence that pollutants are leaving the site or are not properly contained on site?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
12	Are traffic and parking areas restricted so as to reduce soil erosion and dust?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	

#	INSPECTION ITEM	INSPECTOR'S OBSERVATION	ACTION REQUIRED?	NOTES
13	Are non-stormwater discharges properly controlled?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
14	Is the project being operated in compliance with the SWPPP and with permit conditions at this time?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input checked="" type="radio"/> Yes <input type="radio"/> No	Address all the items listed in the SWPPP inspection report.
15	Are changes to the SWPPP necessary at this time?	<input type="radio"/> Yes <input checked="" type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
16	Are dust control measures being properly implemented?	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	
17	Are the SWPPP documentation and records up to date and accurately reflect the current conditions? (e.g. Site Map, Inspection Reports, Installation Dates)	<input checked="" type="radio"/> Yes <input type="radio"/> No <input type="radio"/> N/A	<input type="radio"/> Yes <input checked="" type="radio"/> No	

CERTIFICATION AND SIGNATURE BY INSPECTOR

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

INSPECTED BY:

Kasey Anderson

DATE:

August 24, 2020

SIGNATURE AND AFFILIATION:



CERTIFICATION AND SIGNATURE BY PERMITTEE

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

PRINT NAME AND TITLE:

,

DATE:

SIGNATURE: