

Date: 09/16/19

# After Rain Event Construction Compliance Inspection For

Contractor: Klinger Constructors

Site: Swim Labs

Conducted By: Jeff Hart

Time of visit: 09:45

## Part 1: Walk through the facility and look for signs of erosion control measures that may have failed or been damaged from the recent rainfall event.

a. Site Inspection	Y	N	Notes
1. Are there any erosion control structures damaged from the rain event?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Fabric fence in the NW corner requires re-trench or wattle at base of fence.
2. Are there signs of new ruts or gullies from the rain event?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
3. Are there signs of significant amounts of mud in the street or outfalls from the rainfall event?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	NW corner, at sidewalk, cleared and swept of escaped sediment.
4. Are there any conditions that need immediate attention?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	

## Part 2: Inspection report summary.

b. Inspection Report Summary	Information/Comments
1. Name of Inspector	Jeff Hart
2. Qualifications of Inspector	Training and work experience – see inspector qualification page in the SWPPP
3. Measures/Areas Inspected	Entire Site.
4. Observed Conditions.	Best management practices in place.
5. Changes Necessary to the SWPPP.	None.
6. Were there any discharges?	Yes Fabric fence in the NW corner undermined, cleared and swept of escaped sediment.
What did the water look like at the time of the discharge?	N/A
7. Clear <input type="checkbox"/> Partly sandy <input type="checkbox"/> Very sandy	
8. Was Inspection Conducted Within 24 Hours of Last Rainfall Over 1/4"? How much did it rain?	Yes 09/14= 0.94"; 09/15= 0.13".

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature:



Printed Name: Jeff Hart

Date: 09/16/19

Title: Inspector

**SWPPP Management Signature** \_\_\_\_\_ **Date:** \_\_\_\_\_