

CITY OF ALBUQUERQUE



September 14, 2016

Ron Hensley, P.E.
THE Group
Ron@thegroup.cc

**Re: Holly Estates Subdivision
Erosion and Sediment Control Plan
Engineer's Stamp Date 8-27-16 (C21E040)**

Dear Mr. Hensley,

Based upon the information provided in your submittal received 9-14-16, the above referenced plan is approved to be included in the SWPPP and to include in the Work Order Construction plans with the following condition:

Provide inlet protection, that does not cover the grate (e.g. wattle/mulch sock), for the inlet located in the cul-de-sac.

Include a copy of the approved plan in the Work Order construction plans.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

Copy: e-mail