

CITY OF ALBUQUERQUE



July 17, 2015

Scott J. Steffen, P.E.
BOHANNAN-HUSTON, INC.
7500 Jefferson Street NE Courtyard I
Albuquerque, NM 87109

RE: Montecito West Unit 2 Pad Cert Lots 1-5 and 8-12
Engineers Stamp dated 3/6/14
Engineers Certification dated 7-6-15

Dear Mr. Steffen,

Based upon your Engineer's Certification received 7-6-15, the above referenced plan is acceptable for Building Permit approval on above listed lots.

Lots 6 and 7 were excluded from approval, because Lot 6 has a construction entrance and concrete wash-out station on it and Lot 7 is torn up, is a little loose and has a lot of boulders on it. I've included photos in the e-mail and discussed this with Pulte Homes.

PO Box 1293

If you have any questions, you can contact me at 924-3420.

Albuquerque

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality for Hydrology
Planning Dept.

New Mexico 87103

www.cabq.gov

Copy: Peter Steen, Pulte Homes

July 6, 2015

Ms. Rita Harmon
Hydrology Section
City of Albuquerque
600 2nd Street NW
Albuquerque, NM 87102

Re: Partial Grading and Drainage Certification, Montecito West Unit 2
DRB Case No. 1009506, (D09/D004)

Dear Rita:

We are submitting a partial grading and drainage certification for Montecito West Unit 2. The partial certification includes lots 1-12. Enclosed for your review is the approved grading and drainage plan dated 3/6/14, with as-built elevations.

During site inspection you might notice that there are depressions in the back yards. The purpose of the depressions is to provide a place to spoil dirt that is generated with the footing construction and they will be filled at the time of home construction. The depressions are not intended to serve as ponds.

After reviewing these as-built elevations and visiting the site on 07/03/15, it is my belief that the above lots have been graded in substantial compliance with the approved grading and drainage.

Your review and approval is requested for Building Permit Approval for the above listed lots. I appreciate your time and consideration. If you have questions or require additional information, please contact me at 823-1000.

Sincerely,



Scott J. Steffen, P.E.
Vice President
Community Development & Planning

Enclosure

cc: Peter Steen, Pulte Homes
Kevin Patton, Pulte Homes

Engineering ▲

Spatial Data ▲

Advanced Technologies ▲



City of Albuquerque

Planning Department

Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET

(REV 02/2013)

Project Title: _____ Building Permit #: _____ City Drainage #: _____

DRB#: _____ EPC#: _____ Work Order#: _____

Legal Description: _____

City Address: _____

Engineering Firm: _____ Contact: _____

Address: _____

Phone#: _____ Fax#: _____ E-mail: _____

Owner: _____ Contact: _____

Address: _____

Phone#: _____ Fax#: _____ E-mail: _____

Architect: _____ Contact: _____

Address: _____

Phone#: _____ Fax#: _____ E-mail: _____

Surveyor: _____ Contact: _____

Address: _____

Phone#: _____ Fax#: _____ E-mail: _____

Contractor: _____ Contact: _____

Address: _____

Phone#: _____ Fax#: _____ E-mail: _____

TYPE OF SUBMITTAL:

- _____ DRAINAGE REPORT
- _____ DRAINAGE PLAN 1st SUBMITTAL
- _____ DRAINAGE PLAN RESUBMITTAL
- _____ CONCEPTUAL G & D PLAN
- _____ GRADING PLAN
- _____ EROSION & SEDIMENT CONTROL PLAN (ESC)
- _____ ENGINEER'S CERT (HYDROLOGY)
- _____ CLOMR/LOMR
- _____ TRAFFIC CIRCULATION LAYOUT (TCL)
- _____ ENGINEER'S CERT (TCL)
- _____ ENGINEER'S CERT (DRB SITE PLAN)
- _____ ENGINEER'S CERT (ESC)
- _____ SO-19
- _____ OTHER (SPECIFY)

CHECK TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

- _____ SIA/FINANCIAL GUARANTEE RELEASE
- _____ PRELIMINARY PLAT APPROVAL
- _____ S. DEV. PLAN FOR SUB'D APPROVAL
- _____ S. DEV. FOR BLDG. PERMIT APPROVAL
- _____ SECTOR PLAN APPROVAL
- _____ FINAL PLAT APPROVAL
- _____ CERTIFICATE OF OCCUPANCY (PERM)
- _____ CERTIFICATE OF OCCUPANCY (TCL TEMP)
- _____ FOUNDATION PERMIT APPROVAL
- _____ BUILDING PERMIT APPROVAL
- _____ GRADING PERMIT APPROVAL
- _____ PAVING PERMIT APPROVAL
- _____ WORK ORDER APPROVAL
- _____ GRADING CERTIFICATION
- _____ SO-19 APPROVAL
- _____ ESC PERMIT APPROVAL
- _____ ESC CERT. ACCEPTANCE
- _____ OTHER (SPECIFY)

WAS A PRE-DESIGN CONFERENCE ATTENDED: _____ Yes _____ No _____ Copy Provided

DATE SUBMITTED: _____ By: _____

Requests for approvals of Site Development Plans and/or Subdivision Plats shall be accompanied by a drainage submittal. The particular nature, location, and scope to the proposed development defines the degree of drainage detail. One or more of the following levels of submittal may be required based on the following:

1. **Conceptual Grading and Drainage Plan:** Required for approval of Site Development Plans greater than five (5) acres and Sector Plans
2. **Drainage Plans:** Required for building permits, grading permits, paving permits and site plans less than five (5) acres
3. **Drainage Report:** Required for subdivision containing more than ten (10) lots or constituting five (5) acres or more
4. **Erosion and Sediment Control Plan:** Required for any new development and redevelopment site with 1-acre or more of land disturbing area, including project less than 1-acre than are part of a larger common plan of development

