



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

|                            |   |                                      |  |
|----------------------------|---|--------------------------------------|--|
| Project Name:              | La Cuentista Subdivision All Builders and Developer |                                      |  |
| Location:                  | Goldenseal, Burdock and Buckthorn                   |                                      |  |
| Site Contact Name & Agency | Josh, Bob, Kevin                                    | ESC File No.                         | D10E002B, D10E002B_A, D10E002B_H   |
|                            |   | NPDES Id. No.                        | various  |
| Inspection Date:           | 06/10/20  | Start/End Time:                      | 0930/1200hrs   |
| CoA Stormwater Inspector:  | Timothy E. Sims                                     |                                      |  |
| Construction Phase:        | home construction                                   |                                      |  |
| Type of Inspection:        | <input checked="" type="checkbox"/> Regular         | <input type="checkbox"/> Storm Event | <input type="checkbox"/> Post Storm Event >0.25" <input type="checkbox"/> 311/Complaint <input type="checkbox"/> Follow Up |

|   |          |                |     |
|---|----------|----------------|-----|
| Weather at time of inspection?                | Clear    | Temperature: ~ | 69* |
| Estimated date of last storm 0.25" or greater | 6/1/2020 |                |     |

| Item Number | Deficiency/ Corrective Action  |           |                     |
|-------------|--|-----------|---------------------|
| 1           | Please provide latest SWPPP self-inspection report   |           |                     |
| 2           | Inlet protection requires maintenance. Please mitigate.  |           |                     |
| 3           | Washouts require mitigation and utilization of provided washout facility.  |           |                     |
| 4           | Domestic waste not in acceptable container. Please ensure trades are disposing of waste in acceptable maner.   |           |                     |
|             |  |           |                     |
|             |  |           |                     |
|             | All parties included with this development are copied with this inspection. Lot ownership is unclear to SWQ at this time...Please mitigate portions of the site each builder has control over. |           |                     |
|             |  |           |                     |
|             |  |           |                     |
|             |  |           |                     |
|             |  |           |                     |
|             |  |           |                     |
|             |  |           |                     |
|             |  |           |                     |
|             |  |           |                     |
| 2.1         | Discharge off site? (Y/N)  | No        |                     |
| 4           | Self Inspection Reports  | requested | Latest report Date: |

|        |  |
|--------|--|
| Notes: |  |
|        |  |
|        |  |
|        |  |
|        |  |
|        |  |

City of Albuquerque Stormwater Inspector Signature and date:  
Contact information: Timothy E. Sims - (505) 803-6155  
[tsims@cabq.gov](mailto:tsims@cabq.gov) 06/10/20