

CITY OF ALBUQUERQUE



December 3, 2018

Bob Prewitt, DR Scott LLC, prewitt@swcp.com
Kelley Fetter, E2RC, kfetter@e2rc.com

Site: La Cuentista Unit 2

Re: Drainage Ordinance (14-5-2-1) Violations for Construction Site Waste(s)

Dear Mr. Prewitt,

The following violations were observed at today's inspection.

1. Numerous concrete wash-outs on a lot.
2. Wash-out in the street.
3. Debris not in a waste container.

Photos are shown below:



Numerous wash-outs on a lot.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

CITY OF ALBUQUERQUE



Wash-out in the street.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov



Debris not in a waste container.

**Required Mitigation:**

1. Remove concrete wash-outs that aren't in an acceptable wash-out facility.
2. Have workers use an acceptable concrete wash-out in the future.
3. Remove debris pile.

If violations are not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you would like to schedule a follow-up inspection at a day and time of your convenience, prior to 30 days from the date of this letter please let me know.

If you have any questions, you can contact me at 924-3420.

Sincerely,

A handwritten signature in black ink that reads 'Curtis a Cherne'.

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov