



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	La Cuentista II - DR Horton				
Location:	Burdock				
Site Contact Name & Agency	Kevin Griffin	ESC File No.	D10E002A_H		
	DR Horton	NPDES Id. No.	nmr1001s6		
Inspection Date:	02/20/19	Start/End Time:	1430/1530hrs		
CoA Stormwater Inspector:	Timothy Sims, Stormwater Inspector				
Present Phase of Construction:	wall construction				
Type of Inspection: <input checked="" type="checkbox"/> Regular <input type="checkbox"/> Storm Event <input type="checkbox"/> Post Storm Event >0.25" <input type="checkbox"/> 311/Complaint <input type="checkbox"/> Follow Up					

Weather at time of inspection? Clear	Temperature: ~ 37*
---	--------------------

Has there been a storm event since site was Permitted?

Clarify amount: (i.e.. <1/4" to >3/4"):	yes, >3/4"
--	------------

Inspection

CGP Section	BMP / Activity	Maintenance or Corrective Action Required	Location and Notes
1.5	Post a Notice		
2.2.1	Provide and maintain Natural buffer when Waters of the US <50ft.		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.3	Sediment control along any perimeter		
2.2.4	Minimize sediment track out	x	sediment in streets - please sweep

2.2.5	Manage stock piles		
2.2.6	minimize dust		
2.2.10	Protect storm drain inlets		
2.2.10	Protect storm drain inlets		
2.2.11	Minimize erosion of conveyance channels		
2.2.12	Sediment Basins		
2.2.14	Stabilize exposed portions of the site		
2.2.14	Stabilize exposed portions of the site		
2.2.14	Stabilize exposed portions of the site		
2.2.14	Stabilize exposed portions of the site		
2.3.1	Equipment and vehicle fueling		
2.3.2	Equipment and vehicle washing		
2.3.3	Building material storage		
2.3.3	Fuel, oil, hydraulic fluid, petroleum products and chemical storage		
2.3.3	Construction and domestic wastes		
2.3.3	Construction and domestic wastes		
2.3.4	Washing applicators used for paint, stucco, concrete, etc.		
2.3.4	Washing applicators used for paint, stucco, concrete, etc.		
2.3.4	Washing applicators used for paint, stucco, concrete, etc.		
2.4	Dewatering		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports		Latest report Date: 2/18/2019

Notes: (City Inspector Use) Items in compliance can be left blank.

¹ Construction General Permit (CGP)

Maintenance or corrective actions are to be completed within seven (7) days.

Notes:	
minor sweeping of streets required	

City of Albuquerque Stormwater Inspector Signature and date: _____
Contact information: Timothy Sims, 505-803-6155 or 02/20/19
tsims@cabq.gov