



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	La Cuentista w/ DR Horton				
Location:	Basil and Goldenseal				
Site Contact Name & Agency	Kevin Griffin-DR Horton	ESC File No.	D10E002B_H		
	ktgriffin@drhorton.com	NPDES Id. No.	NMR1001S6		
Inspection Date:	07/22/19	Start/End Time:	1200/1230hrs		
CoA Stormwater Inspector:	Timothy E. Sims				
Construction Phase:	home construction				
Type of Inspection:	☒ Regular	☐ Storm Event	☐ Post Storm Event >0.25"	☐ 311/Complaint	☐ Follow Up

Weather at time of inspection?	Clear/ Windy	Temperature: ~	85*
Estimated date of last storm 0.25" or greater	7/7/2019		

Item Number	Deficiency/ Corrective Action		
1	Please provide latest SWPPP self-inspection report		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	requested	Latest report Date:

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Timothy E. Sims - (505) 803-6155
tsims@cabq.gov 07/22/19