



Arizona  
California  
Colorado  
Kansas  
Louisiana  
Missouri  
Nebraska  
New Mexico  
Texas  
Utah

September 9, 2016

Curtis Cherne, PE  
Principal Engineer, Stormwater Quality  
City of Albuquerque Planning Department  
600 2<sup>nd</sup> Street NW 87102

RE: **La Cuentista Subdivision – Unit II Erosion and Sediment Control Plan - Resubmittal**  
(D10E002B) WCI #1460008900

Dear Curtis:

Attached hereto please find a re-submittal of the Erosion and Sediment Control Plan, previously submitted 6-21-16. We have addressed your comments as indicated below.

For ESC Permit for Grading:

- 1) Silt fence was added on the north side of lots 31-36
- 2) Silt fence was added around the pond outlet structure

For ESC Permit for Building Permit:

- 1) Comments were generally addressed for this section, however, as specific Erosion Control BMP's during homebuilding stage will be presented in the Owner's SWPPP, general information or notes were provided rather than specifics, as per Erosion Control note 12.
- 2) Inlet protection provided per general notes and detail. Modifications for development of subdivision over time will be presented on the Owner's SWPPP.
- 3) Longitudinal street slopes were added to the Plan.
- 4) Interim erosion control methods were added to the Plan.
- 5) Inlet protection detail for construction of infrastructure was changed to be appropriate for roadway inlets.
- 6) Electronic copy of ESC provided via email as requested.

Please call if you have questions or comments at 348-4191. Thank you for your help.

WILSON & COMPANY

  
Kristine Susco  
Project Designer

*Wilson & Company, Inc., Engineers & Architects*

 **HIGHER**  
*Relationships*  
discipline | intensity | collaboration  
shared ownership | solutions