



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	D10E003A	Project Name:	Tiburon Homes Subdivision		
NPDES Id. No.	NMR1001PP	Location:	Tiburon Hills and Trestle Glen		
5/5/2021	Owner	Contractor			
Operator	Rhett Ashley Homes	Rhett Ashley Homes			
Contact name & title	Rhett Waterman	Mike Fitt			
e-mail	watermanrhett@comcast.net	mikef43@q.com			
Contact Phone #	505-917-6157				
COA Inspector	Thomas Evans	Start/End Time:	2:10 PM/2:15 PM		
Construction Phase:	Home construction				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	clear	Temperature:	~ 74		
Estimated date of last storm 0.25" or greater	5/3/2021				
Item Number	Deficiency/ Corrective Action				
1	No posting of permit coverage. Post signage of permit coverage in a location visible to the public.				
2	Construction waste on the ground. Place construction waste in an approved waste container.				
3	No inlet protection. Place inlet protection BMP to prevent sediment from entering the inlet.				
4	Sediment on the sidewalks. Maintain cut-backs and sediment controls to prevent sediment from getting on the sidewalks and in the street.				
5					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	3/19/2020	

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
 Contact information: Thomas Evans (505-803-6215)
tevans@cabq.gov

Thomas Evans 05/06/2021