

## **Elliott, Stanice**

---

**From:** Elliott, Stanice  
**Sent:** Tuesday, January 10, 2017 11:41 AM  
**To:** 'David Soule'  
**Subject:** 6405 Picardia

David

This email is being sent in lieu of an attached comment letter in order to expedite the response for initial reviews. Responses to comments should continue to be included in the re-submittal. A reply to this email with responses to comments will not be considered a re-submittal.

Based upon the information provided in your submittal received 12-12-2016, the above referenced plan cannot be approved for PERM CO until the following comments are addressed:

- The grades on site do not match grades on the approved grading and drainage plan
- Provide as-built grades
- Ensure that the grades match the approved SAD 228 Master Drainage Plan.

Stanice 'Totten' Elliott  
Planning Department  
Hydrology Section  
City of Albuquerque  
505-924-3982  
505-924-3864 fax