

# CITY OF ALBUQUERQUE

*Planning Department*  
Brennon Williams, Director



*Mayor Timothy M. Keller*

June 8, 2021

David Soule, P.E.  
Rio Grande Engineering  
PO Box 93924  
Albuquerque, New Mexico 87199

**RE: Lot 13 Block 10 SAD 228  
Volcano Cliffs Subdivision Unit 22  
6300 Petirrojo Rd. NW  
Grading and Drainage Plan  
Engineers Stamp Date 3/22/2017 (D10D003F13A)  
Pad Certification Date 5/10/2021  
CO Certification Dated: 5/11/2021**

PO Box 1293

Dear Mr. Soule,

Albuquerque

Based upon the information provided in your submittal received 5/28/2021, this plan cannot be approved for Certificate of Occupancy until the following comments are addressed.

- Site needs protection from erosion.

NM 87103

If you have any questions, please contact me at 924-3986 or Rudy Rael at 924-3977.

Sincerely,

www.cabq.gov

Ernest Armijo, P.E.  
Principal Engineer, Planning Dept.  
Development Review Services