

CITY OF ALBUQUERQUE



June 15, 2015

Steve Metro, P.E.
Metro Development Inc.
8860 Desert Finch Ln NE
Albuquerque, New Mexico 87122

**RE: Lot 15 Block 2 Unit 19 Volcano Cliffs
6508 Camino del Oeste
Grading and Drainage Plan
Engineers Stamp Date 5/15/15 (D10D003G15)**

Dear Mr. Metro,

Based upon the information provided in your submittal received 5/15/15, this plan cannot be approved for Grading Permit and Building Permit until the following comments are addressed.

- Provide pond bottoms and WSE.
- Provide pond volumes.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

If you have any questions, please contact me at 924-3695 or Rudy Rael at 924-3977.

Sincerely,

Rita Harmon, P.E.
Senior Engineer, Hydrology
Planning Department

RR/RH
C: File