



Mayor Timothy M. Keller

April 26, 2022

Jesse Luehring, P.E.
Critical View Engineering, LLC
11501 Modesto Ave NE
Albuquerque, New Mexico 87122

**RE: Lot 10 Block 9 Unit 18 SAD 228
6528 Papagayo Pl. NW
Volcano Cliffs Subdivision
Grading and Drainage Plan
Engineers Stamp Date 11/12/2021 (D10D003I10)
CO Certification Date: 4/21/2022**

PO Box 1293

Mr. Luehring,

Albuquerque

Based on the Certification received on 4/25/2022, the site is acceptable for release of Certificate of Occupancy by Hydrology.

NM 87103

If you have any questions, you can contact me at 924-3986 or Rudy Rael at 924-3977.

www.cabq.gov

Sincerely,

Ernest Armijo, P.E.
Principal Engineer, Planning Dept.
Development Review Services



City of Albuquerque

Planning Department
Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 6/2018)

Project Title: G & D for 6528 Papagayo Rd **Building Permit #:** **Hydrology File #:** D10D003110
DRB#: **EPC#:** **Work Order#:**
Legal Description: Lot 10 Block 9 Volcano Cliffs Unit 10 SAD 228
City Address: 6528 Papagayo Rd.

Applicant: Critical View Engineering **Contact:** Jesse Luehring
Address: PO Box 90073, Albuquerque NM, 87199
Phone#: 505-321-5917 **Fax#:** **E-mail:** criticalviewabq@gmail.com

Other Contact: Owner **Contact:** John Apodaca
Address: 6528 Papagayo Rd NW, Albuquerque NM 87120
Phone#: 505-428-1830 **Fax#:** **E-mail:** john.apodaca1@sfcc.edu

TYPE OF DEVELOPMENT: PLAT (# of lots) X RESIDENCE DRB SITE ADMIN SITE

IS THIS A RESUBMITTAL? Yes X No

DEPARTMENT TRANSPORTATION X HYDROLOGY/DRAINAGE

Check all that Apply:

TYPE OF SUBMITTAL:

- ENGINEER/ARCHITECT CERTIFICATION
- PAD CERTIFICATION
- CONCEPTUAL G & D PLAN
- X GRADING PLAN
- DRAINAGE REPORT
- DRAINAGE MASTER PLAN
- FLOODPLAIN DEVELOPMENT PERMIT APPLIC
- ELEVATION CERTIFICATE
- CLOMR/LOMR
- TRAFFIC CIRCULATION LAYOUT (TCL)
- TRAFFIC IMPACT STUDY (TIS)
- STREET LIGHT LAYOUT
- OTHER (SPECIFY)
- PRE-DESIGN MEETING?

TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

- BUILDING PERMIT APPROVAL
- X CERTIFICATE OF OCCUPANCY
- PRELIMINARY PLAT APPROVAL
- SITE PLAN FOR SUB'D APPROVAL
- SITE PLAN FOR BLDG. PERMIT APPROVAL
- FINAL PLAT APPROVAL
- SIA/ RELEASE OF FINANCIAL GUARANTEE
- FOUNDATION PERMIT APPROVAL
- GRADING PERMIT APPROVAL
- SO-19 APPROVAL
- PAVING PERMIT APPROVAL
- GRADING/ PAD CERTIFICATION
- WORK ORDER APPROVAL
- CLOMR/LOMR
- FLOODPLAIN DEVELOPMENT PERMIT
- OTHER (SPECIFY)

DATE SUBMITTED: 4/21/22 **By:** Jesse Luehring

COA STAFF:

ELECTRONIC SUBMITTAL RECEIVED:

FEE PAID:

Critical View Engineering

PO Box 90073

Albuquerque, NM 87199

505-321-5917

April 21, 2022

Rudy E. Rael BS, CE, CFM
City of Albuquerque, Planning Department
Assistant Engineer, CRS Coordinator, Hydrology

RE: COO Certification by Engineer of Record (D10D003I10)

Property Desc: Lot #10, Block #9, Volcano Cliffs Unit #10

I, Jesse J. Luehring, NM Professional Engineer #21684, working on behalf of Critical View Engineering, LLC, hereby certify that the overall grading of the subject property is in substantial conformance to the approved plans dated 11/12/21, and will drain in accordance with the design intent. All 'as-built' elevations are shown on the attached plan.

The record information edited onto the original design document has been obtained under my supervision, and is true and correct to the best of my knowledge and belief. This certification is for the exterior concrete parking pad elevation and site grading, and is submitted to support the Certificate of Occupancy for this residence. Note that original COO for the construction of the home had previously been granted. These improvements were only for the adjacent site grading and construction of a new parking pad.

Note that the record information presented herewith is not necessarily complete and intended only to verify substantial compliance of the grading and drainage aspects of the property. Those relying on this record document are advised to obtain independent verification of its accuracy.

Very Respectfully,



Jesse Luehring, PE


Attached: Revised Plan reflecting actual site conditions



4/21/22

Drainage Calculations

Lot 10, Block 9, Volcano Cliffs Subdivision									
Land Type	Area Lot (SF)	Property Area %	SAD 228 DMP Develop Conditions	100-Yr Storm Inch Depth (6 hr)	100-Yr Excess Precip (In)	Peak Discharge CFS/AC	Peak Rate of Discharge (CFS)	100-Yr Storm Volume (Ac-Ft)	Req. SWQV Volume (Ac-Ft)
Type D	5233	34%	50%	2.17	2.24	4.12	0.49	0.022	0.004205
Type C	1500	10%	40%	2.17	0.95	2.87	0.10	0.003	-
Type B	8766	57%	10%	2.17	0.73	2.16	0.43	0.012	-
	15499	100%	100%				1.03	0.037	0.004205
Total Drainage Basin Area:		15499 SF				Peak Discharge:	1.028 CFS		
		0.356 AC				Stormwater Quality Volume:	183.2 Cubic Ft		
						100-Yr Storm Volume:	1628.8 Cubic Ft		



FEMA Flood Map

35001C0111G VICINITY MAP:

D-10-Z

General Notes

1. All perimeter walls shall be permitted with appropriate agencies
2. No grading shall be allowed on adjacent properties unless permission is received from property owner
3. All disturbed areas shall be stabilized with concrete, gravel, asphalt, or native seed mix
4. It is recommended to contract with a licensed geotechnical engineer for all aspects of earthwork and engineered fill material

Narrative:

This is a grading and drainage plan for the construction of the site improvements including perimeter garden walls and a side yard concrete pad for the residence at address 6528 Papagayo Rd NW (UPC 101006326530910143)

The purpose of this plan is to establish the location of site improvements and general lot drainage of the site. This property previously received a grading permit in support of the pad construction (D10D003110-Stamped 5/12/20), however full implementation of the lot grading was never fully constructed. This plan captures the current state of the property and intends to support final configuration for a fully developed and landscaped property. In addition to the considering the aforementioned plan, this drainage plan has been prepared in accordance with the latest revision to the City of Albuquerque Development Process Manual, and in accordance with the SAD 228 Drainage Report dated November 2011. There are negligible offsite flows entering this property. The site is located in rainfall 'Zone 1' per the DPM.

Drainage Intent:

Existing Conditions: This lot is an 0.35 acre property with a single family home built an a previously permitted building pad. The property is bound to the West by undeveloped land, to the East by a property with an established building pad, and to the South by a developed subdivision with large retaining wall. The existing building pad for the property consists of import fill, as the natural elevation of the lot (and neighboring properties) is lower than the elevation of the road. It generally drains to the west, with negligible offsite flows. The SAD 228 DMP places this property in drainage basin 201-H, and assumes that flows will drain West or North to the street, eventually discharging into Pond 5 at the West end of SAD 228 development.

Proposed Conditions: Improvements to the lot include garden walls and a concrete driveway on the West side that will add approximately 770 SF of impervious area, bringing the total 'Type D' land cover to 34% of the property area (SAD 228 DMP allows up to 50%). The lot is designed to drain to the street, in accordance with the SAD 228 DMP.

A stormwater quality detention pond BMP will be constructed with a volume of 190 Cu. Ft. This feature is designed to capture and infiltrate the DPM required stormwater quality volume of approximately 183 CF. Storm event flows in excess of this volume will discharge from this water quality detention pond at the NW corner of the property by overflowing the existing sidewalk and into Papagayo Rd.

Stormwater Quality Volumes (DPM 6-12):

The required Stormwater Quality Volume to be managed on this lot is for a 0.62" storm (new development). After accounting for initial abstraction, this results in a net of 0.42" rainfall on impervious (Type D) soils, or 183 cubic feet of detention storage for this property. The initial storage on site will be collected and held in the landscape pond near the street as shown on the Plan.

