

# CITY OF ALBUQUERQUE

Planning Department  
Brennon Williams, Director



Mayor Timothy M. Keller

May 19, 2021

Jackie McDowell, PE  
McDowell Engineering, Inc.  
7820 Beverly Hills Ave NE  
Albuquerque, NM 87121

RE: **Lot 3 Block 4 Unit 18, S.A.D. 228**  
**Volcano Cliffs Subdivision**  
**6612 Papagayo Rd. NW**  
**Grading and Drainage Plan**  
**Engineers Stamp Date 5/19/2021 (D10D003J3)**

Ms. McDowell,

Based upon the information provided in your submittal received 5/19/2021, this plan is approved for Grading Permit.

PO Box 1293

**Prior to Building permit approval a Pad Certification will be required, provided by the Engineer or a registered Land Surveyor.**

Albuquerque

Please inform the builder/owner to attach a copy of this approved plan to the construction sets in the permitting process prior to sign-off by Hydrology.

NM 87103

Reiterate to the Owner/Contractor that a separate permit for a garden/retaining wall must be obtained, with the approved G&D plan. **Also, let the Owner/General contractor know that a dirt ramp to climb the curb is not allowed, if dirt is used this will cause a delay in the approval process.**

[www.cabq.gov](http://www.cabq.gov)

Prior to Certificate of Occupancy release, Engineer Certification per the DPM checklist of this plan will be required.

If you have any questions, please contact me at 924-3986 or Rudy Rael at 924-3977.

Sincerely,

Ernest Armijo, P.E.  
Principal Engineer, Planning Dept.  
Development Review Services



# City of Albuquerque

Planning Department  
Development & Building Services Division

## DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 6/2018)

**Project Title:** CANDELARIA - TEDSTROM LOT 3 **Building Permit #:** \_\_\_\_\_ **Hydrology File #:** \_\_\_\_\_  
**DRB#:** \_\_\_\_\_ **EPC#:** \_\_\_\_\_ **Work Order#:** \_\_\_\_\_  
**Legal Description:** LOT 3, BLOCK 4, UNIT 18, VOLCANO CLIFFS SUB'D  
**City Address:** 6612 PAPAGAYO RD NW ALBUQUERQUE NM 87120

**Applicant:** MCDOWELL ENGINEERING, INC. **Contact:** JACKIE MCDOWELL  
**Address:** 7820 BEVERLY HILLS AVE. NE, ALBUQUERQUE, NM 87122  
**Phone#:** 505-828-2430 **Fax#:** 505-821-4857 **E-mail:** jackmcdowell@comcast.net

**Other Contact:** DIEGO CANDELARIA **Contact:** DIEGO CANDELARIA  
**Address:** 1330 Crestview Dr. Los Lunas, NM 87035  
**Phone#:** 505-480-5608 **Fax#:** \_\_\_\_\_ **E-mail:** diego@candelariahomes.com

**TYPE OF DEVELOPMENT:** \_\_\_\_\_ PLAT (# of lots) ☒ RESIDENCE \_\_\_\_\_ DRB SITE \_\_\_\_\_ ADMIN SITE

IS THIS A RESUBMITTAL? \_\_\_\_\_ Yes ☒ No

**DEPARTMENT** \_\_\_\_\_ TRANSPORTATION ☒ HYDROLOGY/DRAINAGE

Check all that Apply:

### TYPE OF SUBMITTAL:

- \_\_\_\_\_ ENGINEER/ARCHITECT CERTIFICATION
- \_\_\_\_\_ PAD CERTIFICATION
- \_\_\_\_\_ CONCEPTUAL G & D PLAN
- ☒ GRADING PLAN
- \_\_\_\_\_ DRAINAGE REPORT
- \_\_\_\_\_ DRAINAGE MASTER PLAN
- \_\_\_\_\_ FLOODPLAIN DEVELOPMENT PERMIT APPLIC
- \_\_\_\_\_ ELEVATION CERTIFICATE
- \_\_\_\_\_ CLOMR/LOMR
- \_\_\_\_\_ TRAFFIC CIRCULATION LAYOUT (TCL)
- \_\_\_\_\_ TRAFFIC IMPACT STUDY (TIS)
- \_\_\_\_\_ STREET LIGHT LAYOUT
- \_\_\_\_\_ OTHER (SPECIFY) \_\_\_\_\_
- \_\_\_\_\_ PRE-DESIGN MEETING?

### TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

- ☒ BUILDING PERMIT APPROVAL
- \_\_\_\_\_ CERTIFICATE OF OCCUPANCY
- \_\_\_\_\_ PRELIMINARY PLAT APPROVAL
- \_\_\_\_\_ SITE PLAN FOR SUB'D APPROVAL
- \_\_\_\_\_ SITE PLAN FOR BLDG. PERMIT APPROVAL
- \_\_\_\_\_ FINAL PLAT APPROVAL
- \_\_\_\_\_ SIA/ RELEASE OF FINANCIAL GUARANTEE
- \_\_\_\_\_ FOUNDATION PERMIT APPROVAL
- ☒ GRADING PERMIT APPROVAL
- \_\_\_\_\_ SO-19 APPROVAL
- \_\_\_\_\_ PAVING PERMIT APPROVAL
- \_\_\_\_\_ GRADING/ PAD CERTIFICATION
- \_\_\_\_\_ WORK ORDER APPROVAL
- \_\_\_\_\_ CLOMR/LOMR
- \_\_\_\_\_ FLOODPLAIN DEVELOPMENT PERMIT
- \_\_\_\_\_ OTHER (SPECIFY) PAD CERTIFICATION


**DATE SUBMITTED:** 5-19-21 **By:** JACKIE MCDOWELL

COA STAFF:


ELECTRONIC SUBMITTAL RECEIVED: \_\_\_\_\_

FEE PAID: \_\_\_\_\_





- GENERAL DRAINAGE PLAN NOTES:
- It is recommended that the Owner obtain a Geotechnical Evaluation of the on-site soils prior to foundation/structural design.
  - This plan recommends positive drainage away from all structures to prohibit ponding of runoff adjacent to the structure. Future alterations of the grades next to the structures are not recommended.
  - Irrigation within 10 feet of any proposed structure is not recommended. Irrigation water adjacent to the structures could cause settlement.
  - This plan establishes on-site drainage and assumes no responsibility for subsurface analysis, foundation or structural design, or utility design.
  - Local codes may require all footings to be placed in natural undisturbed soil. If the contractor plans to place footings on engineered fill, a certification by a registered Professional Engineer is recommended.
  - It is recommended that the Owner obtain the services of a Geotechnical Engineer to test and inspect all earthwork aspects of the project.
  - The property boundary shown on this plan is given for information only to describe the project limits. Property boundary information shown hereon does not constitute a boundary survey.
  - All work shall be constructed in accordance with the City of Albuquerque Standard Specifications for Public Works Construction with updates.
  - All work on this project shall be performed in accordance with applicable Federal, State, and Local laws, rules, and regulations concerning construction safety and health.
  - Contact or shall ensure that no site soils/sediment or silt enters the right-of-ways during construction.
  - Areas disturbed due to construction shall be restored per City of Albuquerque Spec. 1012 native seed mix.



This is the plan to be used for any garden walls and any openings in the walls shall be placed 3" above final grade in the rear yard to allow for cross lot drainage from west to east (upstream to downstream).


PROPERTY LINE WALLS AND GARDEN WALLS SHALL HAVE TURNED BLOCKS OR WEEP HOLES FOR DRAINAGE. ALL OPENINGS IN THE WALLS SHALL BE 3" ABOVE GRADE.

STANDARD GRADING NOTE: THE MAXIMUM GRADED SIDE SLOPE SHALL NOT EXCEED 3 FEET (HORIZONTALLY) TO 1 FOOT (VERTICALLY). AREAS DISTURBED BY GRADING WHICH WILL NOT BE TREATED WITH LANDSCAPING SHALL BE SEEDDED.

STANDARD WALL AND PAD CERTIFICATION NOTES:

ALL PERMITTER GARDEN WALLS SHALL BE PERMITTED SEPARATELY.

A PAD CERTIFICATION IS REQUIRED BEFORE THE BUILDING PERMIT IS RELEASED.



DRAINAGE PLAN

SCOPE:

Pursuant to the latest City of Albuquerque and Bernalillo County Ordinances, the Drainage Plan shown hereon outlines the drainage management criteria for controlling developed runoff on and exiting the project site. A single family home is proposed for the site with associated parking, access, landscaping, and utility improvements.

EXISTING CONDITIONS:

Presently, the 0.52 acre site is undeveloped. The site is bounded on the west, south, and east by private property, and on the north by Papagayo Rd. NW. The site slopes from the northwest to the southeast. As shown on FEMA Panel #111G, the site is not located in a 100 year flood plain.

PROPOSED CONDITIONS:

Per the SAD 227 and 228 Drainage Reports by Wilson & Company, drainage from the lots have been master planned to be intercepted by drainage features downstream of the properties. First flush ponding is required on all developments. As shown by the plan, the building is located in the center of the lot. Negligible off-site flows enter the site due to existing grades from the west and will continue to be allowed to historically flow through the site. On site flows will drain around the structure to new grades and flow to the ponding areas. All roof drainage will discharge from the roof to the lot and be directed around the structure to the drainage paths.

Supplemental calculations are shown as part of this Grading and Drainage plan.

CALCULATIONS:

The calculations shown hereon define the 100 year-6 hour design storm falling within the project area under existing and developed conditions. The Hydrology is per "Section 22.2, Hydrology of the Development Process Manual, Volume 2, Design Criteria, for the City of Albuquerque, New Mexico in cooperation with Bernalillo County, New Mexico and the Albuquerque Metropolitan Arroyo Flood Control Authority.

PROPERTY ADDRESS:


6612 PAPAGAYO RD NW, ALBUQUERQUE, NM 87120

TOPOGRAPHY:

Topographic information provided by Anthony Harris dated May, 2021.

ZONE 1						
P(360) = 2.20 inches						
P(10 day) = 3.67 inches						
Areas: (acres)	Existing	Proposed				
Treatment A	0.52	0.00				
Treatment B	0.00	0.12				
Treatment C	0.00	0.12				
Treatment D	0.00	0.28				
Total (acres) =	0.52	0.52				
Volume	100 year Existing	100 year Proposed	10 year Existing	10 year Proposed	2 year Existing	2 year Proposed
Volume (acre-feet) =	0.019	0.063	0.003	0.036	0.000	0.018
Volume (cubic feet) =	831	2,725	151	1,549	0	788
FIRST FLUSH REQUIRED POND VOL = 0.34"/(12"/FT)*(0.28 AC * 43560 SF/AC) = 346 CF						
Total Q(p), cfs:	100 year Existing Q(p)*A	100 year Proposed Q(p)*A	10 year Existing Q(p)*A	10 year Proposed Q(p)*A	2 year Existing Q(p)*A	2 year Proposed Q(p)*A
Treatment A	0.67	0.00	0.12	0.00	0.00	0.00
Treatment B	0.00	0.24	0.00	0.09	0.00	0.00
Treatment C	0.00	0.34	0.00	0.18	0.00	0.06
Treatment D	0.00	1.22	0.00	0.81	0.00	0.47
Total Q (cfs) =	0.67	1.81	0.12	1.08	0.00	0.53

EAST POND VOLUME PROVIDED:		
ELEV.	AREA	VOL. (CF)
5329	899	310.5
5328.5	343	
WEST POND VOLUME PROVIDED:		
ELEV.	AREA	VOL. (CF)
5329	580	169
5328.5	96	
TOTAL		479.5



LEGEND	
EXISTING	PROPOSED
CONTOUR	6045
PROPERTY LINE	
ROAD	
SETBACK	
RETAINING WALL/WALL	
SPOT ELEVATION	x5321.78

- SURVEY GENERAL NOTES:
- CONTOUR INTERVAL IS ONE (1) FOOT.
  - ELEVATIONS ARE BASED ON CITY OF ALBUQUERQUE STATION No. "ACS BM14-D10", HAVING AN ELEVATION OF 5322.212, NAVD 1988.
  - UTILITIES SHOWN HEREON ARE IN THE APPROXIMATE LOCATION BASED ONLY ON ABOVE GROUND EVIDENCE FOUND IN THE FILED AND AS-BUILT INFORMATION PROVIDED BY THE CLIENT. UTILITIES SHOWN HEREON, WHETHER INDICATED AS ABANDONED OR NOT, SHALL BE VERIFIED BY OTHERS FOR EXACT LOCATION AND/OR DEPTH PRIOR TO EXCAVATION OR DESIGN CONSIDERATIONS.
  - THIS IS NOT A BOUNDARY SURVEY. APPARENT PROPERTY CORNERS AND PROPERTY LINES ARE SHOWN FOR INFORMATION ONLY. BOUNDARY DATA SHOWN IS FROM PREVIOUS SURVEY REFERENCE HEREON.
- SURVEY LEGEND
- CB = CURB  
EC = EDGE OF CONCRETE  
FL = FLOWLINE  
G = GROUND

Jackie S. McDowell  
Professional Engineer  
5-19-21

ENGINEER'S CERTIFICATION:

I, Jackie S. McDowell, hereby certify that I personally inspected the site shown on this plan on May 10, 2021 and as of that date it appeared that no filling, grading, or excavation had occurred thereon since completion of the topographic survey used to prepare this plan.

6612 PAPAGAYO RD NW ALBUQUERQUE NM 87120

CITY OF ALBUQUERQUE, BERNALILLO COUNTY NEW MEXICO

LOT 3, BLOCK 4, UNIT 18  
VOLCANO CLIFFS SUBDIVISION

CANDELARIA HOMES (TEDSTROM) - G & D PLAN

**McDowell Engineering, Inc.**

7820 BEVERLY HILLS AVE. NE • ALBUQUERQUE, NM 87122  
TELE: 505-828-2430 • FAX: 505-821-4857

Designed JSM Drawn STAFF Checked JSM Sheet of  
File CAN0121L Date MAY, 2021 1 1