

# CITY OF ALBUQUERQUE



May 27, 2015

Brad Bingham, P.E.  
Bingham Engineering  
Albuquerque, NM

RE: **SAD 228 Residence**  
**6601 Cuervo PL NW**  
**Grading and Drainage Plan**  
**Engineers Stamp Date 5/11/15 (D10D003J7)**

Dear Mr. Bingham,

Based upon the information provided in your submittal received 5/19/2015, the above referenced Grading and Drainage Plan cannot be approved for Grading Permit or Building Permit until the following comments are addressed.

- Provide a site plan and FIRMette of this location.
- Provide a table of calculations for land treatments, percentages, existing and proposed flows.
- Provide a legal description of this site.
- Show or mention the location of the bench mark.

PO Box 1293

If you have any questions please contact me at 924-3695 or Rudy Rael at 924-3977.

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)

Sincerely,

Rita Harmon, P.E.  
Senior Engineer, Hydrology  
Planning Department

RR/RH  
C: File