

# CITY OF ALBUQUERQUE

Planning Department  
Suzanne Lubar, Director



Mayor Richard J. Berry

June 20, 2017

Jackie McDowell, PE  
McDowell Engineering, Inc.  
7820 Beverly Hills Ave NE  
Albuquerque, NM 87121

RE: **Lot 31 Block 6 Unit 18, S.A.D. 228**  
**6543 Pato Rd. NW**  
**Grading and Drainage Plan**  
**Engineers Stamp Date 6-19-17 (D10D003M31)**

Dear Ms. McDowell,

PO Box 1293

Based upon the information provided in your submittal received 6/19/17, this plan is cannot be approved for Grading Permit until the following comments are addressed

Albuquerque

- Provide the calculations for the openings in the North and South rear yard walls for flows heading North to South, as well as the southwest corner rear yard wall for flows heading from east to west.

New Mexico 87103

**The plan has been modified with the added calculations and wall opening note.**

If you have any questions, please contact me at 924-3695 or Rudy Rael at 924-3977.

www.cabq.gov

Sincerely,

James D. Hughes, P.E.  
Principal Engineer, Hydrology  
Planning Department

RR/JDH  
C: File