

## **Elliott, Stanice**

---

**From:** Elliott, Stanice  
**Sent:** Wednesday, December 14, 2016 10:50 AM  
**To:** David Soule  
**Subject:** 6604 Kimmick NW

David

This email is being sent in lieu of an attached comment letter in order to expedite the response for initial reviews. Responses to comments should continue to be included in the re-submittal. A reply to this email with responses to comments will not be considered a re-submittal.

Based upon the information provided in your submittal received 12-12-2016, the above referenced plan cannot be approved for PERM CO until the following comments are addressed:

- The turn blocks in the backyard "every 20 at 3" Ex Grade" are missing.
- The turn blocks in the front yard are missing.

If you have any question please do not hesitate to contact me.

Stanice 'Totten' Elliott  
Planning Department  
Hydrology Section  
City of Albuquerque  
505-924-3982  
505-924-3864 fax