

CITY OF ALBUQUERQUE

Planning Department
David Campbell, Director



Mayor ~~Timothy~~ M Keller

April 10, 2018

David Soule, PE
Rio Grande Engineering
1606 Central SE Suite 201
Albuquerque, NM 87106

**Re: Lot 5 Block 10 Volcano Cliffs SAD 227 Unit 5
7909 Marigold NW
Request Permanent C.O. - Accepted
Engineer's Stamp dated: 8-31-17 (D10D035)
Certification dated: 4-9-18**

PO Box 1293

Dear Mr. Soule,

Albuquerque

Based on the Certification received 4/9/2018, the site is acceptable for release of Certificate of Occupancy by Hydrology.

NM 87103

If you have any questions, you can contact me at 924-3986 or Rudy Rael at 924-3977.

www.cabq.gov

Sincerely,

James D. Hughes, P.E.
Principal Engineer, Hydrology
Planning Department

RR/JDH
C: File D10D035



City of Albuquerque

Planning Department

Development & Building Services Division

DRAINAGE AND TRANSPORTATION INFORMATION SHEET (REV 09/2015)

Project Title: _____ **Building Permit #:** _____ **City Drainage #:** _____

DRB#: _____ **EPC#:** _____ **Work Order#:** _____

Legal Description: _____

City Address: _____

Engineering Firm: _____ **Contact:** _____

Address: _____

Phone#: _____ **Fax#:** _____ **E-mail:** _____

Owner: _____ **Contact:** _____

Address: _____

Phone#: _____ **Fax#:** _____ **E-mail:** _____

Architect: _____ **Contact:** _____

Address: _____

Phone#: _____ **Fax#:** _____ **E-mail:** _____

Other Contact: _____ **Contact:** _____

Address: _____

Phone#: _____ **Fax#:** _____ **E-mail:** _____

Check all that Apply:

DEPARTMENT:

- ☐ HYDROLOGY/ DRAINAGE
☐ TRAFFIC/ TRANSPORTATION
☐ MS4/ EROSION & SEDIMENT CONTROL

TYPE OF SUBMITTAL:

- ☐ ENGINEER/ ARCHITECT CERTIFICATION
- ☐ CONCEPTUAL G & D PLAN
☐ GRADING PLAN
☐ DRAINAGE MASTER PLAN
☐ DRAINAGE REPORT
☐ CLOMR/LOMR
- ☐ TRAFFIC CIRCULATION LAYOUT (TCL)
☐ TRAFFIC IMPACT STUDY (TIS)
☐ EROSION & SEDIMENT CONTROL PLAN (ESC)
- ☐ OTHER (SPECIFY) _____

CHECK TYPE OF APPROVAL/ACCEPTANCE SOUGHT:

- ☐ BUILDING PERMIT APPROVAL
☐ CERTIFICATE OF OCCUPANCY
- ☐ PRELIMINARY PLAT APPROVAL
☐ SITE PLAN FOR SUB'D APPROVAL
☐ SITE PLAN FOR BLDG. PERMIT APPROVAL
☐ FINAL PLAT APPROVAL
☐ SIA/ RELEASE OF FINANCIAL GUARANTEE
☐ FOUNDATION PERMIT APPROVAL
☐ GRADING PERMIT APPROVAL
☐ SO-19 APPROVAL
☐ PAVING PERMIT APPROVAL
☐ GRADING/ PAD CERTIFICATION
☐ WORK ORDER APPROVAL
☐ CLOMR/LOMR
- ☐ PRE-DESIGN MEETING
☐ OTHER (SPECIFY) _____

IS THIS A RESUBMITTAL?: ☐ Yes ☐ No

DATE SUBMITTED: _____ **By:** _____

COA STAFF: _____ ELECTRONIC SUBMITTAL RECEIVED: _____

Weighted E Method

| Basin | Area | | Treatment A | | Treatment B | | Treatment C | | Treatment D | | Weighted | | Volume | Flow |
|----------|----------|---------|-------------|---------|-------------|---------|-------------|---------|-------------|---------|----------|---------|--------|------|
| | (sf) | (acres) | % | (acres) | % | (acres) | % | (acres) | % | (acres) | (ac-ft) | (ac-ft) | | |
| ALLOWED | 14304.00 | 0.3242 | 0% | 0 | 100% | 0.0304 | 0% | 0.1369 | 50% | 0.170 | 1.248 | 0.041 | 1.21 | |
| PROPOSED | 14304.00 | 0.3242 | 0% | 0 | 31% | 0.106 | 37% | 0.1266 | 32% | 0.109 | 1.204 | 0.034 | 1.06 | |
| total | | | | | | | | | | | | | | |

Equations:

Weighted E = Es**A*a + Eb**A*b + Ec**A*c + Ed**A*d / (Total Area)

Volume = Weighted D * Total Area

Flow = Qa * *A*a + Qb * *A*b + Qc * *A*c + Qd * *A*d

Where for 100-year, 6-hour storm, zone 1
Ea= 0.44
Eb= 0.16
Ec= 0.59
Ed= 1.97
Qa= 1.29
Qb= 2.16
Qc= 2.87
Qd= 4.37

ONSITE Conditions
FIRST FLUSH WATER QUALITY VOLUME
REQUIRED (CF) 135
PROVIDED (CF) 791
WATER QUALITY

Narrative

This site is within the SAD 227 Master Drainage plan boundaries. The site is to maintain existing patterns and drain to the adjacent roadway per the master drainage plan. We are ponding the water harvest volume generated by the site. This site has existing solid walls that eliminate upland flow. The adjacent front yard to the west is allowed to enter the site and discharge over the sidewalk. This plan is in conformance to the master drainage plan

I David Soule, NMPE 14522 , of the firm Rio Grande Engineering, hereby certify that this project has been graded and will drain in substantial compliance with and in accordance with the design intend of the approved plan dated 8/31/17. The record information edited on the original design document has performed by me or under my direct supervision and is true and correct to the best of my knowledge and belief. The as-built survey was provided by THOMAS PATRICK NMPS 12651. The certification is submitted in support of a request for PERMANENT CERTIFICATE OF OCCUPANCY.

The record information presented heron is not necessarily complete and intended only to verify substantial compliance of the grading and drainage aspects of this project. Those relying on this record document are advised to obtain independent verification of its accuracy before using it for any other purpose



4/9/18

EROSION CONTROL NOTES:

- CONTRACTOR IS RESPONSIBLE FOR OBTAINING A TOPSOIL DISTURBANCE PERMIT PRIOR TO BEGINNING WORK.
- CONTRACTOR IS RESPONSIBLE FOR MAINTAINING RUN-OFF ON SITE DURING CONSTRUCTION.
- CONTRACTOR IS RESPONSIBLE FOR CLEANING ALL SEDIMENT THAT GETS INTO EXISTING RIGHT-OF-WAY.
- REPAIR OF DAMAGED FACILITIES AND CLEANUP OF SEDIMENT ACCUMULATIONS ON ADJACENT PROPERTIES AND IN PUBLIC FACILITIES IS THE RESPONSIBILITY OF THE CONTRACTOR.
- ALL EXPOSED EARTH SURFACES MUST BE PROTECTED FROM WIND AND WATER EROSION PRIOR TO FINAL ACCEPTANCE OF ANY PROJECT.



C1
R=216.09'
L=74.96'
C=74.99'
CB=N58°20'57"E
7=19°52'33"

FIRM MAP: FM35001C0113G

LEGAL DESCRIPTION:
LOT 5 BLOCK 10, VOLCANO CLIFFS UNIT 5


NOTES:

- ALL SPOT ELEVATIONS REPRESENT FLOWLINE ELEVATION UNLESS OTHERWISE NOTED.
- ALL SLOPES SHALL BE 3:1 MAX. AND GRAVEL OR NATIVE SEEDING PRIOR TO CO.
- ANY PERMETER WALLS MUST BE PERMITTED SEPARATELY. ALL RETAINING WALL DESIGN SHALL BE BY OTHERS.
- ALL ON LOT PONDING SHALL BE A MINIMUM OF 10' FROM STRUCTURE

LEGEND

- EXISTING CONTOUR
- EXISTING INDEX CONTOUR
- PROPOSED CONTOUR
- PROPOSED INDEX CONTOUR
- SLOPE TIE
- EXISTING SPOT ELEVATION
- PROPOSED SPOT ELEVATION
- BOUNDARY
- CENTERLINE
- RIGHT-OF-WAY
- EXISTING CURB AND GUTTER
- PROPOSED CMU SCREEN WALL
- 18" MAX RETAINAGE (DESIGN BY OTHERS)

7909



| | | |
|-------------------------|----------------------------------------------------------------------------------------------------------|---------------|
| ENGINEER'S SEAL | 7909- MARIGOLD MARQUEZ RESIDENCE | DRAWN BY WCMU |
| | | |
| 8/31/17 | GRADING AND DRAINAGE PLAN | DATE 8-31-17 |
| | | |
| DAVID SOULE P.E. #14222 | Rio Grande Engineering 1606 CENTRAL AVENUE SE SUITE 201 ALBUQUERQUE, NM 87106 (505) 872-0689 | SHEET # — |
| | | |
| 8/31/17 | 21790-LAYOUT-8-31-17 | JOB # 21790 |
| | | |