From: <u>Mazur, Lynn</u>

To: <u>David Soule</u>; <u>Biazar, Shahab</u>

Subject: RE: A Class RV @ JOURNAL CENTER, Lot 3 - Blue Sky Subdivision (D16/D002A3) AMAFCA Approval

Date: Tuesday, November 15, 2011 2:48:42 PM

Attachments: Blue Sky Plat.PDF

I know the excavation easement width varies, but what is shown on the plan is not even close. I would like it shown about 65 feet as it is on the attached plat (no. 8 is the AMAFCA easement). I will also need and encroachment permit as noted in my email from June 2011.

Albuquerque Metropolitan Arroyo

Flood Control Authority

Lynn M. Mazur, P.E., C.F.M. Development Review Engineer

Phone: (505) 884-2215 Mobile: (505) 362-1273 www.amafca.org

The unauthorized disclosure or interception of e-mail is a federal crime. See 18 U.S.C. § 2517(4). This e-mail is intended only for the use of those to whom it is addressed and may contain information which is privileged, confidential and exempt from disclosures under the law. If you have received this e-mail in error, do not distribute or copy it. Return it immediately with attachments, if any, and notify me by telephone at (505) 884-2215.

From: David Soule [mailto:david@riograndeengineering.com]

Sent: Thursday, November 10, 2011 8:23 AM

To: 'Biazar, Shahab' Cc: Mazur, Lynn

Subject: RE: A Class RV @ JOURNAL CENTER, Lot 3 - Blue Sky Subdivision (D16/D002A3) AMAFCA

Approval

I only dropped of revised plan to Lynn last friday. I dont know if she has had chance to review. Yes i

will send PDF's

Thanks David

From: Biazar, Shahab [mailto:sbiazar@cabq.gov] Sent: Thursday, November 10, 2011 8:22 AM

To: David Soule

Subject: A Class RV @ JOURNAL CENTER, Lot 3 - Blue Sky Subdivision (D16/D002A3) AMAFCA

Approval

Just checking to see if you had an approval letter from AMAFCA on A Class RV @ Journal Center, Lot 3 - Blue Sky Subdivision (D16/D002A3).

Also was wondering if you may have your plans and report PDF format and would not mind emailing those. We are starting to ask Engineers to send us PDFs as well as the hard copy if possible. I believed this would be beneficial both to City as well as the consultants for future researches on the City Drainage Files.

Thanks and have a nice day.

Shahab Biazar, P.E.

Senior Engineer
Planning Department
Development & Building Services Division
600 2nd St. NW, Suite 201
Albuquerque, NM 87102
t 505-924-3695
f 505-924-3864