

From: Sandoval, Gary L.
To: "[Jackie McDowell](#)"; santafetow@gmail.com; "[Ron Montoya](#)"; "[Alexander Finale](#)"
Subject: RE: Santa Fe Tow Lot # 13
Date: Thursday, May 26, 2016 8:49:00 AM

Please reconfigure ADA access from the public ROW. We require a 6 ft. ADA access, but 4ft. minimal. Please resubmit when reconfigured.

Thank You,

Gary Sandoval
Engineer
City Traffic Planning Department
505-924-3675

From: Jackie McDowell [<mailto:JackMcDowell@comcast.net>]
Sent: Thursday, May 26, 2016 8:46 AM
To: santafetow@gmail.com; 'Ron Montoya'; 'Alexander Finale'; 'Jackie McDowell'
Cc: Sandoval, Gary L.
Subject: FW: Santa Fe Tow Lot # 13

Armando, Ron, & Alexander,

I just returned the call from Gary Sandoval (see below) and left him a message letting him know that I had forwarded the most recent comments to you, as you are the one doing the site plan and I don't have the authority to change anything (along with not having the duties to design the site). Let me know if any of you would like to talk to him and I can give him your number, or you can just call him. Please keep me updated on any changes I need to make to the TCL plan and the G&D plan.

Thanks,

Jackie S. McDowell, PE
MCDOWELL ENGINEERING, INC.
7820 Beverly Hills Ave. NE
Albuquerque, NM 87122
Voice: (505) 828-2430
Fax: (505) 821-4857
email: JackMcDowell@comcast.net

From: Sandoval, Gary L. [<mailto:glsandoval@cabq.gov>]
Sent: Thursday, May 26, 2016 8:24 AM
To: Jackie McDowell
Subject: Santa Fe Tow Lot # 13

Please contact me regarding the TCL submittal. The ADA access from the public ROW does need to be reconfigured.

Thank You,

Gary Sandoval
Engineer
City Traffic Planning Department
505-924-3675