

CITY OF ALBUQUERQUE



December 4, 2017

David Soule, P.E.
Inspections Plus Inc.
4382 Alexander Blvd NE
Albuquerque, NM 87107

**Re: Blue Sky RV Storage
Erosion and Sediment Control Plan
Engineer's Stamp Date 11-29-17 (D16E002A6)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 11-30-17, the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit with the condition:

1. The upstream end of the culvert in the southwest corner of the site should be protected and you would need permission from the landowner to the west to place the BMP on their property. It may be better to just protect the upstream end of the culvert.

Include a copy of the approved plan in the Building Permit set.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

C: email