

# CITY OF ALBUQUERQUE



August 27, 2018

Scott C. Anderson  
7604 Rio Penasco NW  
Albuquerque, NM 87XXX

**Re: SF Towing Office**  
**Project Address**  
**Traffic Circulation Layout**  
Engineer's/Architect's Stamp **06-21-18** (D16 - D002A7)

Dear Mr. Anderson,

Based upon the information provided in your submittal received 08-27-18, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

1. Address and legal description. The address seems to be incorrect. Please provide the correct address.
2. Service vehicle and/or refuse vehicle maneuvering must be contained on-site; provide a copy of refuse approval.
3. A 5 ft. keyway is required for dead-end parking aisles.
4. Please specify the location of the refuse/trash container.

Resubmit a revised plan along with fully completed Drainage Transportation Information Sheet to front counter personnel for log in and evaluation by Transportation. PDF copies of the plans and submittal package must be emailed to [PLNDRS@cabq.gov](mailto:PLNDRS@cabq.gov) at time of resubmittal. If you have any questions, please contact me@ (505) 924-3675.

Sincerely,

Mojgan Maadandar  
Associate Engineer, Planning Dept.  
Development Review Services

MM via: email  
C: CO Clerk, File