



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	D16E002A8	Project Name:	RAM Motors RV and Truck		
NPDES Id. No.	NMR1002XO	Location:	810 Jacs Lane		
5/18/2021	Owner	Contractor			
Operator	Amigos Investments, LLC.		Andrew Ortiz Construction		
Contact name & title	Christian Nelson				
e-mail	<a href="mailto:chris@rammotors.net">chris@rammotors.net</a>				
Contact Phone #	505-377-3406		505-615-5839		
COA Inspector	Thomas Evans		Start/End Time:	12:25 PM/12:35 PM	
Construction Phase:	Earthwork, building construction				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?	rain		Temperature:	~ 50	
Estimated date of last storm 0.25" or greater	5/3/2021				
Item Number	Deficiency/ Corrective Action				
1	No posting of permit coverage. Post signage with NOI permit coverage in a location clearly visible to the public.				
2	Silt fence damaged. Repair/maintain silt fences to prevent sediment from exiting the site.				
3					
4					
5					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:		

Notes: The SWPPP is believed to be in the trailer on site according to one of the crew members, but the trailer is locked and the superintendent was not on site.

City of Albuquerque Stormwater Inspector Signature and date:

Contact information: Thomas Evans (505-803-6215)  
[tevans@cabq.gov](mailto:tevans@cabq.gov)

*Thomas Evans* 05/19/2021