



# City of Albuquerque Stormwater Construction Site Inspection Report

## General Information

ESC File No.	D16E002A8	Project Name:	RAM Motors RV and Truck		
NPDES Id. No.	NMR1002XO	Location:	810 Jacs Lane		
9/14/2021	Owner	Contractor			
Operator	Amigos Investments, LLC.		Andrew Ortiz Construction		
Contact name & title	Christian Nelson				
e-mail	chris@rammotors.net				
Contact Phone #	505-377-3706		505-615-5839		
COA Inspector	Doug Hughes		Start/End Time:	10:45 AM	
Construction Phase:	Earthwork, building construction				
Type of Inspection:		Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?		clear		Temperature: ~	85
Estimated date of last storm 0.25" or greater		8/16/2021			
Item Number	Deficiency/ Corrective Action				
1	Silt fence is new, previous concerns mitigated.				
2	The onsite SWPPP is still not up-to-date. The map doesn't show the additional area of land disturbing activities. Still no reports.				
3	Concrete washout is cleaned up.				
4	Construction waste is still in a wire enclosure. The container must have a lid.				
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:		

Notes:	Metal building finish nearly complete. Parking lot cold mix asphalt being spread.

City of Albuquerque Stormwater Inspector Signature and date:  
Contact information: Doug Hughes (505-803-6155)  
[jhughes@cabq.gov](mailto:jhughes@cabq.gov)

9/17/21

*James D. Hughes*