



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	D16E002H	Project Name:	Apple Canyon Gourmet		
NPDES Id. No.	NMR10048T	Location:	1301 Cuesta Abajo Ct NE		
2/28/2022	Owner	Contractor			
Operator	Cloche, LLC	Mickrich contractors			
Contact name & title	Greg Shawver	Jim Rich			
e-mail	Greg@applecanyon.com	Jim@mickrichcontractors.com			
Contact Phone #	332-2000	823-9782			
COA Inspector	Doug Hughes	Start/End Time:	11AM		
Construction Phase:	Stabilization				
Type of Inspection:	Regular	Storm Event	Past Storm Event >0.25"	311/Complaint	Follow Up
Weather at time of inspection?		clear		Temperature: ~	50
Estimated date of last storm 0.25" or greater		1/1/2022			

Item Number	Deficiency/ Corrective Action				
1	SWPPP not up-to-date. Missing map, operator signatures on SWPPP, and Self-inspection Reports. The up-to-date SWPPP must be available on-site.				
2	Sediment in adjacent parking lot at Cuesta Abajo entrance, and trackout pad not positioned correctly and covered with sediment. Either permanently close the entrance or reset the trackout pad to full width of entrance, and pickup and remove sediment on adjacent pavement.				
3					
4					
5					
2.1	Discharge off site? (Y/N)	no			
4	Self Inspection Reports	Requested	Latest report Date:	2/24/2022	

Notes:	RJ Muller is Mickrich SI (505) 934-2116 rjmuller@mickrichcontractors.com
SWPPP has 2017 NOIS for both owner and contractor but no delegation for either.	

City of Albuquerque Stormwater Inspector Signature and date:
 Contact information: Doug Hughes (505) 924-3420
jhughes@cabq.gov

3/9/2022
James D. Hughes