

CITY OF ALBUQUERQUE



September 5, 2014

David Thompson
Thompson Engineering Consultants, Inc.
P.O. Box 65760
Albuquerque, NM 87193

**RE: Assisted Living Center
Erosion and Sediment Control (ESC) Plan (D16E101)
Engineers Stamp Date: 8-07-14**

Dear Mr. Soule:

Based upon your submittal received 8-06-14, the above referenced Erosion Sediment Control (ESC) plan is acceptable for Building.

PO Box 1293


This project requires a National Pollutant Discharge Elimination System (NPDES) permit for storm water discharge for disturbing one acre or more and a Topsoil Disturbance Permit for disturbing $\frac{3}{4}$ of an acre or more.

Albuquerque

If you have any questions, you can contact me at 924-3999.

New Mexico 87103

Sincerely,


Shahab Biazar, P.E.
Acting City Engineer, Planning Dept.
Development Review Services

www.cabq.gov

C: e-mail