City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	1310 Cuesta Arriba		
Location:	1310 Cuesta Arriba Ct		
Site Contact Name & Agency	Jeremy - Mechenbier	ESC File No.	D16E103
	jeremymechenbier@mechenbier.com	NPDES Id. No.	NMR1002NW
Inspection Date:	04/09/20	Start/End Time:	0820/0830hrs
CoA Stormwater Inspector:	Timothy E. Sims		
Construction Phase:	earthwork		

Type of Inspection:		Regular		Storm Event		Post Storm Event >0.25"		311/Complaint	x	Follow Up

Weather at time of inspection?	Clear	Temperature: ~	59*
Estimated date of last storm 0.25" or greater			

Item Number	Deficiency/ Corrective Action			
1	Please provide latest SWPPP self-inspection report.			
~~2~~	~~Provide track out pad and non-dirt ramp. Ramps may be asphalt, wood, or cobble.~~			
3	Please provide perimeter BMP. Either mulch sock or silt fence, also construction of ponds may			
	suffice.			
4	Inlet protection required for the six inlets west on Cuesta Arriba.			
5	Removal of sediment in street the entire width of Cuesta Arriba from Las Lomitas to include the			
	cul-de-sac.			
6	Sediment removal on Las Lomitas from south Cuesta Arriba to 100' north of Cuesta Arriba.			
2.1	Discharge off site? (Y/N)	Yes		
4	Self Inspection Reports	requested	Latest report Date:	not on file

Notes:	Verbal communication with Jeremy Mechenbier on 03/31/2020 addressing same
concerns and issues.	

City of Albuquerque Stormwater Inspector Signature and date: Timothy E. Sims

Digitally signed by Timothy E. Sims
DN: cn=Timothy E. Sims, o=Stormwater Inspectionos, ou=Planning, email=tsims@cabq.gov, c=US
Date: 2020.04.09 14:36:04 -06'00'

Contact information: Timothy E. Sims - (505) 803-6155

tsims@cabq.gov 04/09/20