

Inspections Plus, Inc.

Engineer Stamp



5/15/17

Inspections Plus Inc.
Erosion Control Plan
Standard Details

Erosion Control Notes

1. All perimeter erosion and sediment control measures shall be installed prior to the execution of any grading work and maintained by the grading contractor for the duration of the grading project. Failure to install and maintain erosion control is a violation of State Law and subject to fine.
2. The appropriate erosion control device(s) shall be installed prior to the inception of any land disturbing activity and shall be properly maintained for construction activities.
3. All Erosion Control devices and their installation shall meet the standards prescribed in the current guidelines for storm water management for construction activities.
4. Sediment collected behind the sediment filters and silt fences shall be removed when sediment reaches one third the height of the barrier.
5. Sediment filters and silt fences shall be inspected and maintained no less than weekly or within 24 hours of a rainfall event of 0.5 inches or more. Maintenance shall include but not be limited to sediment removal, barrier repair and / or replacement.
6. Construction Site Entrance: The contractor shall construct as a minimum one stabilized construction entrance at the location shown on the plans. If additional ingress and egress to the construction site is required, the contractor shall coordinate with the construction manager the location of these additional stabilized construction entrances. Usage of non-stabilized for ingress and egress will not be permitted. The stabilized entrances shall be maintained in a condition which will prevent tracking or flowing of sediment onto public right-of-way and paved driving lanes. This may require periodic top dressing with additional stone as conditions warrant. Repair of the entrances or cleaning of the right-of-way and paved driving lanes that have been soiled shall be performed by the contractor at his own expense satisfactory to the construction manager. When necessary, vehicle wheels and tires shall be cleaned to remove sediment prior to entering onto public right-of-way and public streets. When washing is required, it shall be done on an area stabilized with crushed stone.
7. The contractor shall at his own expense, periodically water the site to control dust.
8. Sedimentation and erosion control measures shall be removed following construction or upon permanent stabilization of the disturbed and graded areas, whichever occurs last.
9. All disturbed areas that are not to be paved shall be re-seeded unless noted otherwise.
10. The contractor shall keep the site clean at all times and control dust resulting from the earthwork operation. The contractor shall not track mud onto the public streets.

Project:
Legacy 1 @ Journal Center

Inlet Filter Installation Instructions:



flow and starts filtering sediment and debris before water drops into the inlet.




3. Position the mat. Place Inlet Filter on grate with the net side down, flush to the back edge and extending beyond the grate opening on the front and both sides. The zip ties attach Inlet Filter to the inlet grate cover WITHOUT LIFTING THE GRATE COVER.

4. The filter material covering the inlet can be any material that will prevent the sediment and other foreign matter from entering the storm drain system.

Curb Storm Inlet Protection with Wattles



Stabilized Construction Entrance



Definition

A stabilized entrance is a temporary barrier that is used to prevent sediment from entering the storm drain system.

Purpose

The purpose of the stabilized construction entrance is to prevent sediment from entering the storm drain system.


Conditions where the Practice Applies

1. Stabilized construction entrances shall be located at points of construction ingress and egress.
2. The stabilized entrance shall be constructed of concrete or other durable material.
3. The stabilized entrance shall be maintained in good condition.
4. The stabilized entrance shall be removed when construction is complete.


Design Criteria

1. Length - Minimum of 50'-0".
2. Width - Minimum of 30'-0".
3. Gravel - Gravel shall be placed over the entire surface prior to placing stone.
4. Stone - Stone shall be placed over the gravel in a single layer.
5. Fabric - Fabric shall be placed over the stone in a single layer.
6. Location - A stabilized entrance shall be located at the point of construction ingress and egress.

Concrete Washout Area
For use in High Water Table Areas



Reinforced Silt Fence



Definition

A temporary barrier of Geotextile Class "F" over wire reinforcement used to intercept sediment runoff from small drainage areas.

Purpose

The purpose of silt fence is to reduce runoff where velocity and allow the deposition of suspended sediment to occur.

1. Silt fence provides a barrier that can collect and hold debris and soil, preventing the material from entering critical areas, streams, streets, etc.
2. Silt fence can be used where the installation of a dike would destroy vegetation, roads, etc.

Conditions where the Practice Applies

Silt Fence is limited to intercepting sheet flow runoff from limited distances according to slope. It provides filtering and velocity dissipation to promote gravity settling of sediment.

Design Criteria

Sheet piers must be used. Silt fence should be placed as close to the corner as possible. No section of silt fence should exceed a grade of 3 percent for a distance more than 50 feet. Where ends of the geotextile fabric meet together, the ends shall be overlapped, folded, and sealed to prevent sediment bypass. The length of the flow contributing to silt fence shall conform to the following limitations:

Slope (%)	Slope Breakers	Slope Length (ft.) (Maximum)	Silt Fence Length (ft.) (Minimum)
0-10	0-100	Unlimited	Unlimited
10-20	10-20	250	1,500
20-30	20-30	100	1,000
30-40	30-40	50	500
40+	40+	25	250